



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

C010392

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JULY 2011

OWNER OF OPERATOR (Co.#46)

Victorville, City of
14343 Civic Drive
Victorville, CA 92392-2399

EQUIPMENT LOCATION (Fac.#3069)

Victorville SCLA Central Treatment Facility
So 1/2 Sec 14, T6N R5W
Victorville, CA 92392

Description:

SELECTIVE CATALYTIC REDUCTION SYSTEM (ICE-SCR-03) consisting of: Caterpillar SCR unit (urea injection), reducing NOx to 11 ppmvd, CO to 74 ppmvd and non-methane non-ethane hydrocarbons to 32 ppmvd (all at 15% oxygen). This unit serves gaseous fueled internal combustion generator set ICE-03 (B010295).

CONDITIONS:

1. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.
2. This equipment shall be operated concurrently with the internal combustion engine generator set with valid MDAQMD permit B010295.
3. Urea shall be injected whenever the selective catalytic reduction system has reached or exceeded 430 deg Fahrenheit. Except during periods of startup and shutdown, ammonia slip shall not exceed 5 ppmvd (corrected to 15% oxygen), averaged over three hours.
4. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 4952

SCC: 99999999

Location/UTM(Km):
466E/3830N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victorville, City of
Public Works - Fleet Division

Victorville, CA 92392-2399

By: **COPY**
Brad Poiriez
Executive Director