



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

C012863

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: OCTOBER 2025

OWNER OF OPERATOR (Co.#31)

Southern California Gas Co. - MD
9400 Oakdale Avenue
Chatsworth, CA 91313

EQUIPMENT LOCATION (Fac.#1437)

SCG - Blythe
13100 W 14th Avenue
Blythe, CA 92225

Description:

PLANT 4, TURBINE COMPRESSOR 4, SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM, PHASE II, consisting of: a catalyst and ammonia injection system located within the exhaust stack of combustion turbine compressor number 4 permitted as B012855. Manufactured by Cormetech, Model Elite. Equipment Elevation is 259 feet above sea level.

CONDITIONS:

1. This air pollution control device(s), shall be installed, operated, and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles in a manner consistent with good air pollution control practice for minimizing emissions. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.
[District Rule 1302(C)(2)(a)]
2. This equipment shall be operated concurrently with the combustion turbine compressor number 4 with valid District permit B012855.
[District Rule 1302(C)(2)(a); District Rule 1303(A)]
3. Ammonia shall be injected whenever the selective catalytic reduction system is between 500 and 900 Degrees F. Except during periods of startup and shutdown. Ammonia slip shall not exceed 20 ppmvd (corrected to 15% oxygen), averaged over three hours.
[District Rule 1302; District Rule 1303(A)]
4. The owner/operator shall record and maintain for this equipment the following on site for a minimum of five (5) years and shall provide to District personnel upon request.

Fee Schedule: 7 (h)	Rating: 1 device	SIC: 4922	SCC: 20100201	Location/UTM(Km): 719E/3271N
---------------------	------------------	-----------	---------------	---------------------------------

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Gas Co. - MD
PO Box 2300, SC 9314
Chatsworth, CA 91313-2300

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

- a. Ammonia injection, in pounds per hour; and
 - b. Temperature, in degrees Fahrenheit.
- [District Rule 1302; District Rule 1303(A)]

5. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]