



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

C012889

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JUNE 2023

OWNER OF OPERATOR (Co.#2373)

Kavry Management, LLC/Pro Grow
29122 Rancho Viejo Road, Ste 204
San Juan Capistrano, CA 92675

EQUIPMENT LOCATION (Fac.#3738)

Kavry Management, LLC/Pro Grow (Cult)
17130 Muskrat Avenue, Unit A
Adelanto, CA 92301

Description:

ODOR CONTROL AIR FILTRATION SYSTEM, CANNABIS CULTIVATION consisting of: Quantity of 3 Amaircare Airwash HEPA MultiPro Air Scrubbers used to control VOC and odor. Each unit uses pre-filters and a 25 lb carbon canister called a 14" Ultra VOC filter kit, with an airflow of 690 CFM with carbon canisters, power consumption is 235 Watts (2 AMP), dimensions: 19"W x 20"H x 32"L. Facility Elevation is 2940 feet above sea level.

CONDITIONS:

1. This air pollution control device shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 204]

2. The charcoal/carbon filters used in this Air Filtration System shall be certified by the manufacturer to have a minimum VOC control efficiency of 99.97%. In addition, the charcoal/carbon filters must be changed any time the integral sensor indicates breakthrough has occurred. [District Rule 1302]

3. A log pertaining to the operation of this equipment shall be kept for a period of two (2) years, and must be made available upon request of District personnel. This log shall contain the following information:

- a. The date and time of each charcoal/carbon filter replacement; and,
- b. A copy of the manufacturer's certification of control efficiency for the charcoal/carbon filters.

[District Rule 204]

Fee Schedule: 7 (a)

Rating: 1 device

SIC: 191

SCC: 30299999

Location/UTM(Km): 459E/3825N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Kavry Management, LLC/Pro Grow
29122 Rancho Viejo Road, Ste 204
San Juan Capistrano, CA 92675

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

4.The owner/operator must take all steps necessary to preclude odor migration from this facility, including but not limited to, carbon filter change outs whenever breakthrough is indicated by the integral sensor, keeping doors and windows closed to the maximum extent possible, isolating odor-emitting activities from other areas of the buildings through closing doors and windows, and operating all three air filters continuously during cultivation activities.
[District Rule 402]

5.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]