



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**PERMIT TO OPERATE**

C013303

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: JUNE 2026**

**OWNER OF OPERATOR (Co.#2875)**

United One Adelanto, LLC  
10150 Apache Road  
Adelanto, CA 92301

**EQUIPMENT LOCATION (Fac.#3891)**

United One Adelanto, LLC  
10150 Apache Road  
Adelanto, CA 92301

**Description:**

ODOR CONTROL AIR FILTRATION SYSTEM, CANNABIS consisting of: Quantity of 5 rooms with 4 filters per room. Odor and air pollution filtration control equipment contain activated carbon impregnated filters that are 40 inches in length. Exhaust fan has a fan capacity of 1800 cfm. Facility Elevation is 2933 feet above sea level.

**CONDITIONS:**

1. This air pollution control device shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 204]
2. The charcoal/carbon filters used in this Air Filtration System shall be certified by the manufacturer to have a minimum VOC control efficiency of 99.97%. In addition, the charcoal/carbon filters must be changed any time breakthrough has occurred. [District Rule 1302]
3. A log pertaining to the operation of this equipment shall be kept for a period of two (2) years, and must be made available upon request of District personnel. This log shall contain the following information:
  - a. The date and time of each charcoal/carbon filter replacement; and,
  - b. A copy of the manufacturer's certification of control efficiency for the charcoal/carbon filters.

Fee Schedule: 7 (a)

Rating: 1 device

SIC: 191

SCC: 30299999

Location/UTM(Km):  
459E/3825N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

United One Adelanto, LLC  
10150 Apache Road  
Adelanto, CA 92301

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

[District Rule 204]

4. The owner/operator must take all steps necessary to preclude odor migration from this facility, including but not limited to, carbon filter change outs when breakthrough has occurred, keeping doors and windows closed to the maximum extent possible, isolating odor-emitting activities from other areas of the buildings through closing doors and windows, and operating all three air filters continuously during cultivation activities.

[District Rule 402]

5. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]