



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### RENEWAL

C014206

Renewal type Permit has no description information.

**EXPIRES LAST DAY OF: MAY 2025**

#### **OWNER OF OPERATOR (Co.#2239)**

CalPortland Company  
19409 National Trails Hwy  
Oro Grande, CA 92368

#### **EQUIPMENT LOCATION (Fac.#3)**

CalPortland Oro Grande  
19409 National Trails Hwy  
Oro Grande, CA 92368

#### **Description:**

SELECTIVE NON-CATALYTIC REDUCTION SYSTEM, UREA consisting of: a TBD wet or dry urea SNCR system having a hopper, an agitator, screw conveyor with air assist, and a TBD gallon wet mix tank. This system can operate using either liquid or dry urea.

#### **CONDITIONS:**

1. This equipment must be installed, operated, and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment must also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 204]

2. Annual throughput of dry urea injection is limited to 2,960 tons per year. Owner/operator shall maintain written (or electronic) records to demonstrate compliance with this limit. [District Rule 1303(B)]

3. Owner/operator shall install and maintain urea injection rate measurement equipment. [District Rule 204 and 1320]

4. This equipment shall not discharge into the atmosphere emissions that exhibit greater than ten percent opacity. [District Rules 401, 403; 40 CFR 63.1345]

5. The Owner/Operator shall surrender 42 pounds of PM10 emission reduction credits from ERC certificate 0111 prior to operation of this equipment.

Fee Schedule: 7 (h)      Rating: 1 device      SIC: 3241      SCC: 30500623      Location/UTM(Km): 469E/3830N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CalPortland Company  
Attn: Catalina Elias  
  
Oro Grande, CA 92368

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

[District Rule 1302(C)(3)(b)(v)]

6. Ammonia slip from kiln stack, operating under Permit B007435, shall not exceed 10 ppmvd @ 7% oxygen on a 24-hour average, verified by CEMS. Further, ammonia emissions shall not exceed 9.06 tons per year.  
District Rules 401, 402, and 1320]

7. Ammonia slip shall be monitored using a Continuous Emissions Monitoring System (CEMS). The operator shall install, calibrate, maintain and operate this monitoring system according to a District-approved monitoring plan and Rule 218. Missing CEMS data shall be substituted in accordance with the provisions of 40 CFR Part 75.  
[District Rules 204 and 1320]

8. Owner/operator must conduct an initial ammonia source test within 90 days of placing equipment into operation and every 12 months thereafter, according to the procedures in EPA Test Method 320 Measurement of Vapor Phase Organic and Inorganic Emissions By Extractive Fourier Transform Infrared (FTIR) Spectroscopy, or other applicable test method with prior written approval by the District.

The owner/operator shall conduct all required compliance/certification tests in accordance with the MDAQMD Compliance Test Procedural Manual. Thirty (30) days prior to the compliance/certification tests the operator shall provide a written test plan for District review and approval. Written notice of the compliance/certification test shall be provided to the District ten (10) days prior to the tests so that an observer may be present. A written report with the results of such compliance/certification test shall be submitted to the District within forty-five (45) days after testing  
[District Rules 204 and 1302]

9. Urea injection shall only commence when the kiln is operating under normal production levels, as defined under MDAQMD Rule 1161. Urea injection shall not occur when the kiln is in start-up or shut-down conditions, as defined under MDAQMD Rule 1161.  
[District Rule 1320]

10. Owner/operator shall maintain an operations log for these units current and on-site. This log shall be provided to District, State and Federal personnel upon request and shall include, at a minimum, the information specified below:

- a) All required CEMS data;
- b) Kiln feed rate;
- c) Reagent injection rate;
- d) Results of each compliance test; and
- e) Annual emission summary.

[District Rules 204, 1203(D)(1)(c)&(d) and 1320]

11. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]