



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**AUTHORITY TO CONSTRUCT**

C015048

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

**EXPIRES LAST DAY OF: MAY 2026**

**OWNER OF OPERATOR (Co.#2938)**

2119 Building, Inc.  
7381 Foothill Blvd  
Tujunga, CA 91042

**EQUIPMENT LOCATION (Fac.#4363)**

2119 Building  
2590 Mercantile Way  
Barstow, CA 92311

**Description:**

ODOR CONTROL AND SUPPRESSANT SYSTEM, CANNABIS consisting of: Composed of an odor maskant system comprised of a FOGCo misting system which injects a neutralizing formula (Cannabusters concentrate) into the mist.

**CONDITIONS:**

1. These air pollution control devices shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 204]
2. Odors from this equipment shall be non-detectable. The owner/operator shall conduct quarterly odor detection checks at the exhaust of the above described equipment to ensure that breakthrough has not occurred. If odors are detected, the odor misting system must be properly adjusted, until the odors are no longer detectable. [District Rules 204 and 402]
3. The owner/operator must take all steps necessary to preclude odor migration from this facility, including but not limited to, keeping doors and windows closed to the maximum extent possible, isolating odor-emitting activities from other areas of the buildings through closing doors and windows, and operating all odor control equipment continuously during cultivation activities. [District Rule 402]

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 2833

SCC: 3029999

Location/UTM(Km):  
493E/3856N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

2119 Building, Inc.  
7381 Foothill Blvd  
Tujunga, CA 91042

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

4. A log pertaining to the operation of this equipment shall be kept for a period of two (2) years, and must be made available upon request of District personnel. This log shall contain, as a minimum, the following information:

- a. The date and time of each odor additive refill;
- b. Results of quarterly odor monitoring checks.

[District Rule 204]

5. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]