



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

COC P000005

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JUNE 2026

OWNER OF OPERATOR (Co.#2432)

17K Muskrat 1
8469 Beach Circle
Cypress, CA 90630

EQUIPMENT LOCATION (Fac.#3829)

17K Muskrat 1
17080 Muskrat Avenue
Adelanto, CA 92301

Description:

CANNABIS ODOR COMPLIANCE PLAN consisting of: A facility licensed under the Ca Bus. & Prof. Code Division 10 which started operation on 12/20/2019 and includes cannabis cultivation. Odor is controlled by eight Can-Filter Can 150 carbon canisters, 18 Air Filters Inc. Astro-sorb replaceable carbon air filters (venting to atmosphere), and four Ona Gel fluidized absorbers.

EQUIPMENT

Capacity	Equipment Description
24600	COC P Facility Square feet
0	8 Can-Filter Can 150 60" by 16" 123 lb carbon canisters handling 1019 cfm of flow each
0	18 Air Filters Inc. Astro-sorb 20" by 20" by 2" 14 lb carbon filters handling 4000 cfm of flow each and exhausting to atmosphere.
0	Four Ona Gel 12" x 20" 50 lb fluidized adsorbers

CONDITIONS:

1. The owner/operator shall ensure that this facility does not discharge from any source whatsoever such quantities of odor which cause injury, detriment, nuisance or annoyance to any considerable number of persons or to the public. Compliance with this condition shall be verified by either: (a) no detectable odor at any exterior vent, exterior discharge or exterior container associated with this facility, or (b) no detectable odor at any portion of the fenceline or property boundary of this facility.

Fee Schedule: 13 (a)

Rating: 1 sq. ft.

SIC: 191

SCC: 30299999

Location/UTM(Km):
459E/3825N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

17K Muskrat 1
8469 Beach Circle
Cypress, CA 90630

By: **COPY**
Eldon Heaston
Air Pollution Control Officer