



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### CANNABIS ODOR COMPLIANCE PLAN AUTHORIZATION

COCPP000015

This California Business & Professions Code Division 10 Compliance Plan (Cannabis Odor Compliance Plan) is authorized in response to District Rule 302(J)(5). This authorization is designed to enforce the provisions of Division 26 of the California Health & Safety Code and applicable District Rules and Regulations. Operations covered by this authorization must be conducted in compliance with all information included with the initial filing and requirements specified below. Equipment referenced by this authorization must be maintained and kept in good operating condition at all times. This authorization shall be maintained on site at the location referenced below at all times.

**EXPIRES LAST DAY OF: JUNE 2025**

#### OWNER OF OPERATOR (Co.#2566)

Tikun - Olam Adelanto LLC  
16605 Koala Road  
Adelanto, CA 92321

#### EQUIPMENT LOCATION (Fac.#3984)

Tikun-Olam Adelanto  
16605 Koala Rd  
Adelanto, CA 92301

#### Description:

CANNABIS ODOR COMPLIANCE PLAN consisting of: A facility licensed under the California Business & Professions Code Division 10 which started operation on 11/10/2019 and includes cannabis cultivation, mechanical extraction, winterization, post-extraction refinement/purification, packaging/repackaging and distribution. Odor is controlled by a water misting system and a pre-discharge exhaust iodine misting system. The iodine misting system treats the air prior to external venting.

#### EQUIPMENT

Capacity	Equipment Description
69452	COCPP Facility Square feet
0	Six Marathon Model TVF48617D11001A misting systems handling 30,000 cfm and venting externally through a 54" duct. These systems mist Cannabusters sorbent into the exhaust stream, prior to external venting. This system is used to control odors for the greenhouse cultivation portion of this facility.
0	Ten Can-Fan Max Fan 16" 60" by 16.5" by 2.56" carbon canisters containing 123 pounds of carbon sorbent each and handling 2436 cfm (venting internally). This system is used to control odors for the indoor cultivation portion of this facility.

#### REQUIREMENTS:

Fee Schedule: 13 (a) Rating: 69452 sq. ft. SIC: 191 SCC: 30299999 Location/UTM(Km): 458E/3823N

This plan does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This plan cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This plan must be renewed by the expiration date above. If billing for renewal fee required by Rule 302 is not received by expiration date above, please contact the District.

Tikun - Olam Adelanto LLC  
16605 Koala Road  
Adelanto, CA 92321

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

1.The owner/operator shall ensure that this facility does not discharge from any source whatsoever such quantities of odor which cause injury, detriment, nuisance or annoyance to any considerable number of persons or to the public. Compliance with this condition shall be verified by either: (a) no detectable odor at any exterior vent, exterior discharge or exterior container associated with this facility, or (b) no detectable odor at any portion of the fenceline or property boundary of this facility.