



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

E003507

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JANUARY 2026

OWNER OF OPERATOR (Co.#504)

Adelanto, City of
11600 Air Expressway
Adelanto, CA 92301

EQUIPMENT LOCATION (Fac.#1227)

Adelanto Police Dept HQ
11613 Bartlett Road
Adelanto, CA 92301

Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of:

One Cummins, Diesel fired internal combustion engine Model No. 6BT5.9-G1 and Serial No. 44645650, producing 135 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 6.0 gal/hr. This equipment powers a TBD Generator Model No. 80DGDA39638F and Serial No. H910409644, rated at 80 kW.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.
[40 CFR Part 63, Subpart ZZZZ; Rule 204]

2. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.
[Title 17 CCR 93115; 40 CFR 63.6625(f)]

3. This unit shall only be fired on ultra-low sulfur diesel fuel, whose sulfur concentration is less than or equal to 0.0015% (15 ppm) on a weight per weight basis per CARB Diesel or equivalent requirements.
[17 CCR 93115(e)(1)(A)]

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 9199

SCC: 20100102

Location/UTM(Km): 459E/3826N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Adelanto, City of
11600 Air Expressway

Adelanto, CA 92301

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

4.The owner/operator shall minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes.

[40 CFR Part 63, Subpart ZZZZ 63.6625(h)]

5.This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 20 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 20 hour per year limit.

6.The owner/operator shall maintain an operations log for this engine current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the following information:

- a) Date of each use and duration of each use (in hours);
- b) Reason for use (testing & maintenance, emergency, required emission testing, etc.);
- c) Monthly and calendar year operation in terms of fuel consumption (in gallons) and/or total hours;
- d) Fuel sulfur concentration as required by condition 3 (the owner/operator may use the supplier's certification of sulfur content if it is maintained as part of this log); and,
- e) Maintenance performed on this equipment.

[17 CCR 93115.10(f)]

7.The owner/operator shall conduct inspections in accord with the following schedule. All inspections must occur at least annually regardless of operating hours.

- a) Change oil and filter every 500 hours of operation or annually, whichever comes first, or use an oil change analysis program to extend oil change frequencies per the requirements in 40 CFR 63.6625(i);
- b) Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and
- c) Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

[40 CFR Part 63.6630(a); Table 2d.4.; Subpart ZZZZ]

8.This equipment shall not operate for non-emergency use, including maintenance and testing, during the following periods:

- a) Whenever there is a school sponsored activity; or,
- b) Between 7:30 a.m. and 3:30 p.m. on days when school is in session.

[17 CCR 93115.6(a)(1)]

9.This equipment may operate in response to an impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time. The engine may be operated no more than 30 minutes prior to the forecasted outage and must be shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[17 CCR 93115.6(a)(2)]

10.This unit shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[17 CCR 93115.6(c)(1)(C)]

11.This unit is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines Title 17 CCR 93115 and 40 CFR 63 Subpart ZZZZ (RICE NESHA). In the event of conflict between conditions and the referenced regulatory citations, the more stringent requirements shall govern.

[District Rule 1302]

12.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]