



# MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

## INACTIVE

E003722

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: FEBRUARY 2000**

### OWNER OF OPERATOR (Co.#100)

Metropolitan Water District of So Calif  
158000 MWD Road  
Parker Dam, CA 92267

### EQUIPMENT LOCATION (Fac.#774)

MWD - Iron Mountain Pumping Plant  
6001 Iron Mt Pumping Road  
Earp, CA 92242

#### **Description:**

EMERGENCY STANDBY POWER SYSTEM consisting of: Caterpillar, four cylinder diesel generator rated 110 bhp @ 1800 rpm, Serial No. 60SH295, Model No. 5L4219.

#### **CONDITIONS:**

1. The owner/operator (o/o) is limited to operating this generator to 1.0 hours/week for test purposes and for furnishing electrical power when line power is not available.
2. This equipment is portable and can be used by MWD at other various MWD sites throughout the District. This equipment will be stored at the Iron Mountain Pumping Station when not in use.
3. The o/o shall use only diesel fuel whose sulfur content is less than or equal to 0.05 percent on a weight basis.
4. The o/o shall maintain a log which, as a minimum contains:
  - a. Date and length of time the engine is operated.
  - b. Location where equipment was used.
  - c. Volume and dates of delivery of diesel fuel.
  - d. Sulfur content of the fuel. The o/o may use the supplier's furnished certification of sulfur content if the certifications are maintained on file as part of the log.
5. The o/o shall maintain the logs on-site for a minimum of two (2) years and provide them to District personnel on request.

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4941

SCC: 20100102

Location/UTM(Km): 673E/3780N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Metropolitan Water District of So Calif  
P O Box 54153

Los Angeles, CA 90054

By: **COPY**

**Brad Poiriez**

Air Pollution Control Officer

6.This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District.