



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E003733

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MARCH 2001

OWNER OF OPERATOR (Co.#1034)

A T & T - San Ramon
311 S. Akard Street, 12th Floor
Dallas, TX 75202

EQUIPMENT LOCATION (Fac.#1358)

A T & T - Turquoise Radio Site
15 Miles Northeast of
Baker, CA 92309

Description:

EMERGENCY ELECTRICITY GENERATOR consisting of:

One Caterpillar, Diesel fired internal combustion engine Model No. D379 and Serial No. 68B1109, producing 610 bhp with cylinders at rpm while consuming a maximum of . This equipment powers a Model No. and Serial No. , rated at .

CONDITIONS:

1. The owner/operator (o/o) shall log all starting and stopping times of test periods and emergency use of this unit to the nearest minute; the date(s) of operation and delivery of fuel.
2. The o/o shall not use diesel fuel whose sulfur concentration 3 0.05% on mass per mass basis.
3. The o/o shall use no other fuel but diesel in this unit without the prior written approval of the APCO. The o/o may use a supplier's sulfur analytical data, but at the discretion of the District, shall take a sample of the delivered fuel and submit it for analysis by an independent testing laboratory. The results of said analyses, by ASTM method D 2622-82, shall be logged.
4. The o/o shall maintain the log current, on-site, for a minimum of two years and provided to District personnel on request.
5. This unit shall be used only when commercially available power is interrupted. This unit may also be operated weekly as part of a testing program at this facility, but shall not exceed 60 minutes per week.

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4813

SCC: 20100102

Location/UTM(Km):
583E/3905N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

A T & T - San Ramon
311 S. Akard Street, 12th Floor
Dallas, TX 75202

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

6. This unit shall not be operated more than 1000 hours in any calendar year without the prior written approval of the APCO.