



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E003786

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2001

OWNER OF OPERATOR (Co.#86)

MAGTFTC MCAGCC
Box 788110, Bldg 1418
Twentynine Palms, CA 92278-8110

EQUIPMENT LOCATION (Fac.#591)

USMC AGCC
Box 788110, Bldg. 1451
Twentynine Palms, CA 92278-8110

Description:

EMERGENCY DIESEL GENERATOR AT BLDG 1130, WELL 7A consisting of:

One CUMMINS, Diesel fired internal combustion engine Model No. 3018930 and Serial No. 473129, producing 221.3 bhp with cylinders at rpm while consuming a maximum of. This equipment powers a Empire Generator Model No. 16500 DKW-83 and Serial No., rated at 165.

CONDITIONS:

1. The owner/operator (o/o) shall log the starting and stopping times of the operational periods of this generator, to the nearest minute, and the date.
2. The o/o shall use only diesel fuel whose sulfur concentration is less than or equal to 0.05% by weight or JP-8 fuel.
3. The o/o shall log all purchases of diesel fuel including the volume (or weight), date received and the sulfur content. The o/o may use the supplier's furnished certification of sulfur content if the certifications are maintained on file as a part of the log.
4. The logs shall be maintained current, on-site for a minimum of 2 years and provided to District personnel on request.
5. The o/o is limited to operating this generator to 1.0 hr/wk for test purposes, and for emergency purposes, which is defined as when commercially available power has been interrupted.

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 9711

SCC: 20100102

Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC
Box 788110, Building 1418

Twentynine Palms, CA 92278-8110

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

6.This unit shall not be operated more than 1000 h/year without the prior written approval of the District APCO.