



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E004175

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2004

OWNER OF OPERATOR (Co.#2278)

Frontier California Inc.
280 S. Locust Street
Pomona, CA 91766

EQUIPMENT LOCATION (Fac.#1456)

Frontier - Blythe
400 E Rice Street
Blythe, CA 92225

Description:

EMERGENCY ELECTRIC GENERATOR consisting of:

One Allis Chalmers, Diesel fired internal combustion engine Model No. 25000MK-11 and Serial No. 25-03310, producing 380 bhp with 6 cylinders at rpm while consuming a maximum of . This equipment powers a Model No. and Serial No. , rated at .

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This unit shall be limited to use of emergency power (when commercially available power has been interrupted). The unit may be operated weekly as part of a testing program which does not exceed 60 minutes per week.
3. The owner/operator (o/o) shall use only diesel fuel whose sulfur concentration is equal to or less than 0.05% on a weight per weight basis.
4. The o/o shall maintain a log which, as a minimum, contains:
 - A. Date and length of time the engine is operated.
 - B. Sulfur content of the fuel. The o/o may use the supplier's furnished certification of sulfur content if the certifications are maintained on file as a part of the log.

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4813

SCC: 20100102

Location/UTM(Km):
725E/3273N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Frontier California Inc.
280 S. Locust Street
Pomona, CA 91766

By: **COPY**
Brad Poiriez
Executive Director

5. The o/o shall maintain the log current, on-site for a minimum of two years and provide them to District personnel on request.