



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

E005064

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: NOVEMBER 2003**

**OWNER OF OPERATOR (Co.#88)**

NAWS  
429 E Bowen Road - Stop 4014  
China Lake, CA 93555-6108

**EQUIPMENT LOCATION (Fac.#567)**

NAWCWD Test Stands  
429 E Bowen Road - Stop 4014  
China Lake, CA 935556108

**Description:**

IC ENGINE, EMERGENCY PUMP (BLDG 01111) consisting of:

One Detroit, Diesel fired internal combustion engine Model No. 4061A and Serial No. 331880, producing 124 bhp with cylinders at rpm while consuming a maximum of . This equipment powers a Model No. and Serial No. , rated at .

**CONDITIONS:**

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles.
3. This unit shall be limited to use when commercially available power has been interrupted, and as part of a testing program which does not exceed 60 minutes of operation per week.
4. The owner/operator (o/o) shall use only diesel fuel whose sulfur concentration is less than or equal to 0.05% on a weight per weight basis in this unit.
5. The o/o shall maintain a log for this unit, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of five (5) years and shall be provided to District personnel on request:
  - a. Date of each use;

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 9711

SCC: 20100102

Location/UTM(Km):  
450E/3946N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NAWS  
Environmental Management Division  
  
China Lake, CA 93555-6108

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

- b. Duration of each use, in minutes;
- c. Fuel consumed during each calendar year, in gallons;
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).