



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E005176

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MARCH 1998

OWNER OF OPERATOR (Co.#1034)

A T & T - San Ramon
311 S. Akard Street, 12th Floor
Dallas, TX 75202

EQUIPMENT LOCATION (Fac.#1360)

A T & T - Union Street
16612 Union Street
Victorville, CA 92392

Description:

EMERGENCY ELECTRICAL GENERATOR consisting of: a Caterpillar engine driving a generator. The engine is direct injected, turbo-charged, after cooled, intercooled and has its ignition retarded. The engine is rate at 564 bhp at 1800 rpm and uses a maximum of 29.2 gallons of diesel fuel per hour. The engine model is 3406 DITA with a serial number of 47R02246. The generator is rated at 400 kW(e).

CONDITIONS:

1. The owner/operator (o/o) shall log the starting and stopping times of the operational periods of this generator, to the nearest minute, and the date.
2. The o/o shall use only diesel fuel whose sulfur concentration is less than or equal to 0.05% by weight.
3. The o/o shall log all purchases of diesel fuel including the volume (or weight), date received and the sulfur content. The o/o may use the supplier's furnished certification of sulfur content if the certifications are maintained on file as a part of the log.
4. The logs shall be maintained current, on-site for a minimum of 2 years and provided to District personnel on request.
5. The o/o is limited to operating this generator to 1.0 hr/wk for test purposes, and for emergency purposes, which is defined as when commercially available power has been interrupted.
6. This unit shall not be operated more than 1000 h/year without the prior written approval of the District APCO.

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4813

SCC: 99999999

Location/UTM(Km):
473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

A T & T - San Ramon
311 S. Akard Street, 12th Floor
Dallas, TX 75202

By: **COPY**
Eldon Heaston
Air Pollution Control Officer