



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

E007817

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: DECEMBER 2002**

**OWNER OF OPERATOR (Co.#1329)**

Level 3 Communications  
P.O. Box 1330  
Camarillo, CA 93011

**EQUIPMENT LOCATION (Fac.#2303)**

Level 3 Communications - Primm  
State Line Pass and Keany Pass  
Primm, CA 92366

**Description:**

EMERGENCY GENERATOR consisting of:

One Caterpillar, Diesel fired internal combustion engine Model No. 3406C and Serial No. to be provided, Turbo Charged, producing 449 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 22.0 gal/hr. This equipment powers a Caterpillar Generator Model No. 3406 and Serial No. to be provided, rated at 300kW.

**EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
CO	8.4	gm/bhp-hr
NOx	6.8	gm/bhp-hr
PM10	0.4	gm/bhp-hr
SOx	0.16	gm/bhp-hr
VOC	0.99	gm/bhp-hr

**CONDITIONS:**

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4813

SCC: N/A

Location/UTM(Km):  
643E/3934N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Level 3 Communications  
Holly Ebright  
  
Camarillo, CA 93011

By: **COPY**  
Eldon Heaston  
Air Pollution Control Officer

2. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants.

3. This unit shall be limited to use for emergency power, defined as when commercially available power has been interrupted, and as part of a testing program which does not exceed 60 minutes of operation per week.

4. The owner/operator (o/o) shall use only diesel fuel whose sulfur concentration is less than or equal to 0.05% on a weight per weight basis in this unit.

5. The o/o shall maintain a log for this unit, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:

- a. Date of each use;
- b. Duration of each use, in minutes;
- c. Fuel consumed during each calendar year, in gallons;
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).