



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

E008125

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MAY 2001

OWNER OF OPERATOR (Co.#629)

Specialty Minerals, Inc
6565 Meridian Road
Lucerne Valley, CA 92356

EQUIPMENT LOCATION (Fac.#262)

Specialty Minerals, Inc
6565 Meridian Road
Lucerne Valley, CA 92356

Description:

EMERGENCY COMPRESSOR consisting of:

One Cummins, Diesel fired internal combustion engine Model No. NTA855-C450 and Serial No. 11590628, producing 435 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 21.0 gal/hr. This equipment powers a Ingesoll-Rand Compressor Model No. P1600 and Serial No. , rated at 1600 cfm.

CONDITIONS:

1. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants.
3. This unit shall be limited to use for emergency power, defined as when commercially available power has been interrupted, and as part of a testing program which does not exceed 60 minutes of operation per week (up to two hours once per year for annual testing and up to four hours once every three years for triennial testing).
4. The owner/operator (o/o) shall use only diesel fuel whose sulfur concentration is less than or equal to 0.05% on a weight per weight basis in this unit.

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 1422

SCC: 20200102

Location/UTM(Km):
508E/3803N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Specialty Minerals, Inc
P.O. Box 558
Lucerne Valley, CA 92356

By: **COPY**
Brad Poiriez
Executive Director

5. A timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

6. The o/o shall maintain a log for this unit, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:

- a. Date of each use;
- b. Duration of each use, in minutes;
- c. Annual operation in terms of total calendar year fuel use (in gallons) or hours;
- d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).