



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

E009445

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: JANUARY 2023**

**OWNER OF OPERATOR (Co.#2733)**

NextEra Energy Capital Holdings, Inc.  
700 Universe Blvd.  
Juno Beach, FL 33408

**EQUIPMENT LOCATION (Fac.#941)**

Resurgence Solar & BESS  
41100 Highway 395  
Boron, CA 93516

**Description:**

GASOLINE IC ENGINE, EMERGENCY GENERATOR consisting of:

One Ford, 87U fired internal combustion engine Model No. LSG-8751-6005-A and Serial No. 17806 T-18-TT, producing 87 bhp with 8 cylinders at 1800 rpm while consuming a maximum of 9.0 gal/hr. This equipment powers a Onan Generator Model No. 60EN and Serial No. B890206154, rated at 60 kW.

**EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
CO	211.7	gm/bhp-hr
NOx	8.8	gm/bhp-hr
VOC	2.8	gm/bhp-hr

**CONDITIONS:**

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.
2. Engine may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4911

SCC: 20300301

Location/UTM(Km):  
450E/3874N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NextEra Energy Capital Holdings, Inc.  
700 Universe Blvd.  
Juno Beach, FL 33408

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

the utility advises that the outage is no longer imminent or in effect.

3. This ICE shall only be fired on gasoline.

4. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

5. This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 20 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 20 hour per year limit.

6. The o/o shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a) Date of each use and duration of each use (in hours);
- b) Reason for use (testing & maintenance, emergency, required emission testing); and
- c) Calendar year operation in terms of fuel consumption (in gallons) and total hours.

7. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]

8. Facility-wide emissions must be less than:

- a) 20 tons per year of NO<sub>x</sub>,
- b) 20 tons per year of VOC,
- c) 15 tons per year of PM<sub>10</sub> (basis: offsets),
- d) 10 tons per of any single Hazardous Air Pollutant, and
- e) 25 tons per year of any combination of any Hazardous Air Pollutant.

Facility-wide emissions shall be calculated and recorded, in tons, on a calendar month basis and totaled for each consecutive twelve-month basis. For emergency engines, only emissions generated during testing and maintenance shall apply toward the facility-wide emission limits. These records shall be maintained as current for a minimum of five (5) years, and made available upon District, State and/or Federal request.

[District Rule 221(B) and (C) - Basis: Voluntary Emission Limitations - below Title V]