



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

E009533

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: OCTOBER 2014**

### **OWNER OF OPERATOR (Co.#1654)**

New Cingular Wireless PCS, LLC  
311 S. Akard Street, 12th Floor  
Dallas, TX 75202

### **EQUIPMENT LOCATION (Fac.#2836)**

New Cingular Wireless - Afton Overlay  
45009 Afton Canyon Rd  
Afton, CA 92310

#### **Description:**

PROPANE IC ENGINE, EMERGENCY consisting of: Year of Manufacture - 1996

OneFord Power Products, Propane fired internal combustion engine Model No. CSG 649 and Serial No. K960622669, producing 68 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 242.0 scf/hr. This equipment powers a Onan Generator Model No. 45EM and Serial No. K960622669, rated at 45 kW.

#### **EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
CO	201.76	gm/bhp-hr
HC	2.32	gm/bhp-hr
NOx	0.93	gm/bhp-hr
PM10	0.175	gm/bhp-hr
SOx	0.012	gm/bhp-hr

#### **CONDITIONS:**

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

2. Engine may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating

Fee Schedule: 7 (g)      Rating: 1 device      SIC: 4813      SCC: 20301001      Location/UTM(Km): 555E/3580N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

New Cingular Wireless PCS, LLC  
ATTN: EH&S

Dallas, TX 75202

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.

3.This ICE shall only be fired on propane (LPG).

4.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

5.This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 50 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 50 hour per year limit.

6.The o/o shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (testing & maintenance, emergency, required emission testing); and
- c. Calendar year operation in terms of fuel consumption (in gallons) and total hours.