



# MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

## PERMIT TO OPERATE

E009796

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

### EXPIRES LAST DAY OF: APRIL 2025

#### OWNER OF OPERATOR (Co. #2278)

Frontier California Inc.  
280 S. Locust Street  
Pomona, CA 91766

#### EQUIPMENT LOCATION (Fac. #2917)

Frontier - GC# 755  
15315 Nisqually Rd  
Victorville, CA 92395

#### Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: A certified Tier 1 engine, EPA Family 1CEXL0505AAA, manufactured in 2001 with no exhaust after-treatment device installed. Equipment elevation is 3047 feet above sea level.

One Cummins, Diesel fired internal combustion engine Model No. 6CT8.3-G2 and Serial No. 46131478, Turbo Charged, After Cooled, Compression-Ignited, Direct Injected, producing 207 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 11.0 gal/hr. This equipment powers an Onan Generator Model No. 125DGEA and Serial No. G010262351, rated at 125 kW(e).

#### EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.523	gm/bhp-hr
NOx	5.52	gm/bhp-hr
PM10	0.246	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.298	gm/bhp-hr

#### CONDITIONS:

1. This existing diesel engine shall be installed, operated, and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles, which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

Fee Schedule: 7 (g)      Rating: 1 device      SIC: 4813      SCC: 20100102      Location/UTM(Km): 473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Frontier California Inc.  
280 S. Locust Street  
Pomona, CA 91766

By: **COPY**  
Brad Poiriez  
Air Pollution Control Officer

[District Rule 204]

2.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this equipment to indicate elapsed engine operating time.

[17 CCR 93115.10(d)]

3.This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:

- a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,
- b. A cetane index or aromatic content, as follows:
  1. A minimum cetane index of 40; or,
  2. A maximum aromatic content of 35 volume percent.

[17 CCR 93115.5(a) and 40 CFR 80.510(b)]

Note: Use of CARB certified ULSD fuel satisfies these requirements.

4.This unit shall be limited to emergency use only, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 20 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 20 hour per year limit.

[17 CCR 93115.6(b)]

5.The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours per hour meter);
- b. Reason for use (testing & maintenance, emergency, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in gallons or total hours);
- d. Records of all required maintenance and inspections, and;
- e. Fuel sulfur concentration (the owner/operator may use the supplier's certification of sulfur content if it is maintained as part of this log).

[17 CCR 93115.10(f)]

6.This equipment may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[17 CCR 93115.6(b)(1)]

7.This equipment shall not be used to provide power during a voluntarily agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[17 CCR 93115.6(c)(2)(C)]

8.As authorized in 40 CFR 63.6585(f), this area HAP source engine is currently exempt from the requirements of 40 CFR 63, subpart ZZZZ - the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (the RICE NESHAP).

Upon loss of this exemption, immediate compliance with 40 CFR 63, Subpart ZZZZ is required. Additionally, this existing commercial emergency stationary engine shall not operate for non-emergency use as part of any financial arrangement with any other entity.

[40 CFR 63.6585(f), 40 CFR 63.6640(f), and 40 CFR 63.6675]

9.This engine is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines, Title 17 CCR 93115.

[Title 17 CCR 93115, Rule 1302]

10.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the

District, in a format approved by the District, upon District request.  
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]