



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### PERMIT TO OPERATE

E009851

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: JANUARY 2026**

#### OWNER OF OPERATOR (Co. #1733)

Barstow Fire Protection District  
861 Barstow Rd  
Barstow, CA 92311

#### EQUIPMENT LOCATION (Fac. #2944)

Barstow Fire Protection District  
861 Barstow Road  
Barstow, CA 92311

#### Description:

PROPANE, EMERGENCY GENERATOR consisting of: Year of Manufacturer 2006 with no exhaust after-treatment devices installed. Exhaust flow is 441 acfm at 1049 degrees Fahrenheit.

One Cummins/Ford, NG fired internal combustion engine Model No. WSG-1068 and Serial No. 07YS63868, producing 115 bhp with 10 cylinders at 1800 rpm while consuming a maximum of 789.0 scf/hr. This equipment powers a Cummins Generator Model No. GGHE 60 Hz and Serial No. D070048408, rated at 60 kW(e).

#### EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	8.1	gm/bhp-hr
NOx	11.7	gm/bhp-hr
PM10	0.10	gm/bhp-hr
PM2.5	0.10	gm/bhp-hr
SOx	0.019	gm/bhp-hr
VOC	1.1	gm/bhp-hr

#### CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise

Fee Schedule: 7 (g)      Rating: 1 device      SIC: 9224      SCC: 20201001      Location/UTM(Km): 498E/3962N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Barstow Fire Protection District  
861 Barstow Rd  
Barstow, CA 92311

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.  
[District Rules 204 and 1303]

2.A non-resettable hour meter with a minimum display capability of 9,999 hours shall be installed and maintained on this unit to indicate elapsed engine operating time.  
[District Rule 1302(C)(2)(a)]

3.This unit shall only be fired on PUC-Regulated Natural Gas or commercial grade liquified petroleum gas (LPG) / propane fuel.  
[District Rules 1302 and 1320]

4.This unit shall be limited to emergency use only, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 50 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 50 hour per year limit.  
[District Rule 1302(C)(2)(a)]

5.The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the following information:

- a. Date of each use and duration of each use (in hours per hour meter);
- b. Reason for use (testing & maintenance, emergency, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in standard cubic feet (for natural gas)/gallons (for LPG/Propane) or total hours); and
- d. Records of all required maintenance and inspections.

[District Rule 1302(C)(2)(a)]

6.This unit shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[District Rule 204]

7.This engine may operate in response to a notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[District Rule 1302(C)(2)(a)]

8.As authorized in 40 CFR 63.6585(f), this area HAP source engine is currently exempt from the requirements of 40 CFR 63, subpart ZZZZ - the National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (the RICE NESHAP).

Upon loss of this exemption, immediate compliance with 40 CFR 63, Subpart ZZZZ is required. Additionally, this existing commercial emergency stationary engine shall not operate for non-emergency use as part of any financial arrangement with any other entity.

[40 CFR 63.6585(f), 40 CFR 63.6640(f), and 40 CFR 63.6675]

9.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]