

### MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

### PERMIT TO OPERATE

E010286

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

### **EXPIRES LAST DAY OF: JUNE 2026**

# OWNER OF OPERATOR (Co.#46)

Victorville, City of 14343 Civic Drive Victorville,CA92392-2399

# **EQUIPMENT LOCATION (Fac. #70)**

Victorville - Fleet Maint Yard 14177 McArt Road Victorville,CA92392

### **Description:**

DIESEL IC ENGINE, PORTABLE EMERGENCY SEWER PUMP (86376) consisting of:Year of Manufacture 2008, Tier 3, USEPA Family Name 8JDXL04.5107.

OneJohn Deer, Diesel fired internal combustion engine Model No.4045TF285B-C-D and Serial No.PE4045L039601, Direct Injected, Turbo Charged, producing84 bhp with4 cylinders at2200 rpm while consuming a maximum of4.0gal/hr. This equipment powers aJohn DeerPump Model No.4045TF285B-C-D and Serial No.PE4045L039601, rated at8" sewer pump.

#### **EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
СО	1.715	gm/bhp-hr
NOx	3.057	gm/bhp-hr
PM10	0.142	gm/bhp-hr

# **CONDITIONS:**

1. This certified portable diesel internal combustion engine shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 1302]

Fee Schedule:7 (g)

Rating:1device

SIC:9199

SCC:20200102

Location/UTM(Km):471E/3822N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victorville, City of Public Works - Fleet Division

Victorville, CA92392-2399

By: COPY

Brad Poiriez

Air Pollution Control Officer

Permit:E010286 Issue Date:07/16/2025

2. This diesel engine and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days, excluding time spent at a designated storage site. This equipment must be moved within this facility or moved to another facility annually for a valid operational reason.

[Title 17 CCR 93116.2(a)(29)]

- 3. This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) on a weight per weight basis per CARB Diesel or equivalent requirements; or alternative diesel fuel, or CARB diesel fuel utilizing fuel additives, that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines. [Title 17 CCR 93116.3(a)]
- 4.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time. [Title 17 CCR 93116.4(b)(2)(A)]
- 5.This unit shall be limited to use for emergency power, defined as in response to a fire, mitigation of a flood or sewage overflow, pumping of water to maintain pressure in the water distribution system, training of personnel in the use of portable equipment for emergency purposes, or when commercially available power has been interrupted.

  [Title 17 CCR 93116.2(a)(12)]
- 6. This engine has been designated as "emergency" pursuant to Title 17 CCR 93116 and is therefore exempt from the fleet requirements of sections 93116.3(c)(1) and 93116.3(c)(2) pursuant to section 93116.3(c)(3)(B). In order to maintain this designation, this engine is limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 50 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 50 hour per year limit.

In the event that this engine exceeds the allowed hours of operation in a calendar year it becomes immediately subject to the requirements of section 93116.3(c)(1) or (c)(2) in the year such exceedance or use occurs. The responsible official (owner/operator) must submit a request to convert the engine to regular use, subject to the limitations of section 93116.3(c)(6). [Title 17 CCR 93116.2(a)(23) and 9.3116.3(c)(3)and(5)]

- 7.The owner/operator shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:
- a. Date of each use;
- b. Location of each use (decimal degrees, xx.xxxxx;-yyy.yyyyy);
- c. Duration of each use (in hours as indicated by the hour timer);
- d. Reason for each use (testing & maintenance, emergency, required emission testing);
- e. Calendar year operation in terms of fuel consumption (in gallons) or total hours; and,
- f. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log). [Title 17 CCR 93116]
- 8. This USEPA Tier 3 certified engine, operating as part of a Small Fleet, may not be sold, or offered for sale, to an end user in California on or after January 1, 2027. The sale of engines for resale outside of California is not prohibited.

  [Title 17 CCR 93116.3(e)]
- 9. This engine is subject to the requirements of the Airborne Toxic Control Measure For Diesel Particulate Matter From Portable Engines Rated At 50 Horsepower and Greater (Title 17 CCR 93116). In the event of conflict between these conditions and the ATCM, the more stringent shall govern.

  [Title 17 CCR 93116]
- 10. This unit shall not operate within 1000 feet of the outer boundary of any K-12 school for more than 45 days. Such operation will require the submittal of an application for a revised permit to operate so that the applicable requirements of the California Health and Safety Code Section 42301.6 will be met.

[District Rule 1302 and H&S Code 42301.6]

Page 2 of 3 Permit:E010286 Issue Date:07/16/2025

11.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.  [District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]		

Page 3 of 3 Permit:E010286 Issue Date:07/16/2025