



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

AUTHORITY TO CONSTRUCT

E014864

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

EXPIRES LAST DAY OF: NOVEMBER 2026

OWNER OF OPERATOR (Co. #88)

NAWS
429 E Bowen Road - Stop 4014
China Lake, CA 93555-6108

EQUIPMENT LOCATION (Fac. #4652)

NAVAIR Remote Power Support
429 E Bowen Road - Stop 4014
China Lake, CA 93555

Description:

DIESEL IC ENGINE, EMERGENCY GENERATOR (SWPL) consisting of: A certified Tier 2 diesel engine, EPA Family MVPXL16.1ACC, manufactured in 2021 with no exhaust after-treatment device installed. Exhaust flow is 3,249 ACFM at 851 degrees Fahrenheit.

One Volvo, Diesel fired internal combustion engine Model No. TAD1641GE-B and Serial No. TBD, Four-Stroke Lean Burn, After Cooled, Compression-Ignited, Turbo Charged, producing 757 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 36.8 gal/hr. This equipment powers a Kohler Generator Model No. 500REOZVC and Serial No. TBD, rated at 565 kW.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.26	gm/bhp-hr
NOx	4.15	gm/bhp-hr
PM10	0.03	gm/bhp-hr
PM2.5	0.03	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.104	gm/bhp-hr

CONDITIONS:

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 3812

SCC: 20100102

Location/UTM(Km):
450E/3946N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NAWS
Environmental Management Division

China Lake, CA 93555-6108

By: **COPY**
Brad Poiriez
Executive Director

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.
[District Rule 204; 40 CFR 60.4211(a)]
2. A non-resettable hour meter with a minimum display capability of 9,999 hours shall be installed and maintained on this unit to indicate elapsed engine operating time.
[17 CCR 93115.10(d); 40 CFR 60.4209]
3. The owner/operator must purchase diesel fuel for this engine that meets the requirements of 40 CFR 80.510(b) for nonroad diesel fuel, which are as follows:
 - (a) A sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,
 - (b) A cetane index or aromatic content, as follows:
 - (1) A minimum cetane index of 40; or,
 - (2) A maximum aromatic content of 35 volume percent.
[40 CFR 60.4207(b)]
Note: Use of CARB certified ULSD fuel satisfies the above requirements.
4. This unit shall be limited to emergency use only, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 50 hours per rolling consecutive twelve-month period for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 50-hour rolling annual limit.
STATE AND DISTRICT ENFORCEABLE ONLY
[District Rule 204; 17 CCR 93115.6(b)]
5. This unit shall be limited to emergency use only, as defined in 40 CFR 60.4219. In addition, this unit shall be operated no more than 100 hours per rolling consecutive twelve-month period for testing and maintenance, including compliance source testing.
[District Rule 204; 40 CFR 60.4211(f)]
6. The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:
 - (a) Date of each use and duration of each use (in hours per hour meter);
 - (b) Reason for use (testing & maintenance, emergency, required emission testing);
 - (c) Rolling consecutive twelve-month period operation in terms of fuel consumption (in gallons or total hours);
 - (d) Records of all maintenance and inspections; and,
 - (e) Fuel sulfur concentration (the owner/operator may use the supplier's certification of sulfur content. Such certification may be stored separately from the remainder of the log).
[District Rule 204; 17 CCR 93115.10(f); 40 CFR 60.4214; 40 CFR 70.6(a)(3)(ii)(b)]
7. This unit shall not be used to provide power during a voluntarily agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.
[District Rule 204; 17 CCR 93115.6(a); 40 CFR 60.4211 and 60.4219]
8. This engine may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect.
[District Rule 204; 17 CCR 93115.6(a)]
9. This engine is subject to the requirements of Title 17 CCR 93115, the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines, and 40 CFR 60 Subpart IIII, Standards of Performance for Stationary Compression Ignition Internal

10. This facility has elected to voluntarily limit its emissions to the extent that this facility is no longer subject to the provisions of Regulation XII - Federal Operating Permits [District Rule 221(B)]. As such, the facility-wide emissions must be less than the following limitations in each calendar year:

- (a) 80 tons per year of Carbon Monoxide (CO)
- (b) 25 tons per year of Oxides of Nitrogen (NOx) [More stringent limit is offset based]
- (c) 25 tons per year of Volatile Organic Compounds (VOC) [More stringent limit is offset based]
- (d) 15 tons per year of Particulate Matter of 10 microns or less (PM10) [More stringent limit is offset based]
- (e) 10 tons per year of Hydrogen Sulfide (H2S) [More stringent limit is offset based]
- (f) 25 tons per year of Oxides of Sulfur (SOx)
- (g) 0.5 tons per year of Lead (Pb)
- (h) 8 tons per year of any single Hazardous Air Pollutant (HAP)
- (i) 20 tons per year of any combination of HAP

Compliance with these emission limitations must be verified by pollutant-specific emission summaries for each calendar year. These emission summaries must be retained on-site for a minimum of five (5) years; and, must be made available for review upon request by District, State, and/or Federal personnel.

[District Rules 221(B), 1201(S) and 1303(B) - basis: offsets for NOx, VOC, PM10 and H2S only]

For the purposes of implementation of the Title I (Part D) Nonattainment New Source Review (nonattainment NSR), Title I (Part C) Prevention of Significant Deterioration (PSD), and Title V Operating Permit Programs under the Clean Air Act, Facility refers to a stationary source, or group of stationary sources that are located on one or more contiguous or adjacent properties that are owned, operated, supervised, or controlled by one or more Department of Defense (DoD) component(s) that were disaggregated during the course of major source determination(s), based upon appropriate industrial groupings and support facility relationships. Compliance with these limits shall be demonstrated through the submission of an installation-wide Comprehensive Emission Inventory (CEI) for all emitted regulated air pollutants or any pollutant listed under section 112(b) of the Clean Air Act (including 12 month emissions summary). Exceedance of these emission limits may trigger offsets, BACT, and/or require submission of a Title V permit application. [District Rules 1302 and 1303, 40 CFR 51.165, 40 CFR 52.21(b), 40 CFR 70.2 and "Major Source Determinations for Military Installations under the Air Toxics, New Source Review, and Title V Operating Permit Programs of the Clean Air Act," memorandum from John S. Seitz, Director, Office of Air Quality Planning and Standards, (August 2, 1996)]

11. A Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants located at this military installation (including, but not limited to, MDAQMD Facility nos. 567, 4650, 4651, 4652 and 4653) must be submitted to the District, in a format approved by the District, upon District request. For the purposes of CEI, Facility is defined as every structure, appurtenance, installation, and improvement on land which is associated with a source of air releases or potential air releases of a hazardous material. [District Rule 107(b); H&S Code 39607 & 44341-44342; 17 CCR 93400 et seq.; and 40 CFR 51, Subpart A]