



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### RENEWAL

E015258

Renewal type Permit has no description information.

**EXPIRES LAST DAY OF: JUNE 2025**

#### **OWNER OF OPERATOR (Co.#2281)**

Federal Aviation Administration (Ridgecrest)  
729 S. Richmond Rd  
Ridgecrest, CA 93555

#### **EQUIPMENT LOCATION (Fac.#2500)**

FAA - Velvet Peak ASR  
20 mi N of Barstow 35 03 37/ 117 00 52  
Barstow, CA 92356

#### **Description:**

DIESEL IC ENGINE, EMERGENCY GENERATOR consisting of: A Certified Tier 3 diesel engine, USEPA family RJDXL04.5119, manufactured in 2024. Exhaust flow approximately 805 acfm, at 1076 degrees Fahrenheit through a 8 foot high by 3.86 inches diameter exhaust stack. Equipment is located at an elevation of 4215 feet above MSL.

One John Deere, Diesel fired internal combustion engine Model No. 4045HF2851 and Serial No. TBA, Four-Stroke Lean Burn, Compression-Ignited, Turbo Charged, Charge Air Cooler, Electronic Control Module, Smoke Puff Limiter, producing 158 bhp with 4 cylinders at 1800 rpm while consuming a maximum of 8.2 gal/hr. This equipment powers a Kohler Generator Model No. 100REOZJF and Serial No. TBD, rated at 102 kW.

#### **EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
CO	0.9694	gm/bhp-hr
NOx	2.5056	gm/bhp-hr
PM10	0.1268	gm/bhp-hr
PM2.5	0.1255	gm/bhp-hr
SOx	0.0049	gm/bhp-hr
VOC	0.1119	gm/bhp-hr

#### **CONDITIONS:**

1. This certified Tier 3 stationary compression-ignited internal combustion engine, and any associated air pollution control equipment, shall be installed, operated, and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles, which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be

Fee Schedule: 7 (g)      Rating: 1 device      SIC: 9661      SCC: 20100102      Location/UTM(Km): 498E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Federal Aviation Administration  
(Ridgecrest)  
729 S. Richmond Rd  
  
Ridgecrest, CA 93555

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

operated in accordance with all data and specifications submitted with the application for this permit.  
[40 CFR 60.4211(a)]

2.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this equipment to indicate elapsed engine operating time.  
[17 CCR 93115.10(d)]

3.This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:

- a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,
- b. A cetane index or aromatic content, as follows:
  - (i) A minimum cetane index of 40; or,
  - (ii) A maximum aromatic content of 35 volume percent.

[17 CCR 93115.5(a), 40 CFR 60.4207(b) and 40 CFR 1090.305]

Note: Use of CARB certified ULSD fuel satisfies these requirements.

4.This engine shall be limited to use for emergency power, defined as in response to a fire or flood, or when commercially available power has been interrupted. In addition, this engine shall be operated no more than 50 hours per year for testing and maintenance.  
[District Rule 1303(A); 17 CCR 93115.6(a)(3)(A)(1)(c)]

5.The owner/operator shall maintain an operations log for this equipment current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:

- a. Date(s) of each use and hours of operation;
- b. Reason for use (regular testing & maintenance, NFPA testing & maintenance, emergency, etc.);
- c. Monthly and rolling 12 month period operation in terms of fuel consumption (in gallons) and/or total hours (both emergency and non-emergency use, classified as described in b. above);
- d. Fuel sulfur concentration as required by condition #3 (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log); and,
- e. Maintenance performed on this equipment.

[17 CCR 93115.10(f)]

6.This equipment may operate in response to an impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time. The engine may be operated no more than 30 minutes prior to the forecasted outage and must be shut down immediately after the utility advises that the outage is no longer imminent or in effect.

[17 CCR 93115.6(a)(2)]

7.This equipment shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.

[17 CCR 93115.6(c)(1)(C)]

8.This engine is subject to the requirements of Title 17 CCR 93115, the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines and 40 CFR 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (NSPS). In the event of a conflict between these conditions and the ATCM or NSPS, the more stringent requirements shall govern.

[District Rule 1302]

9.This engine shall not be operated concurrently with the engine covered under District Permit E008425. The operations logs for this unit required by Condition 5 must clearly show the startup date and times to demonstrate compliance with this requirement. Engine permitted under E008425 must be removed from service prior to the startup operation of the new unit permitted under E015258.

[District Rules 1160, 1302 and 1320]

10.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.  
[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]