



# MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

## AUTHORITY TO CONSTRUCT

E015335

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

**EXPIRES LAST DAY OF: FEBRUARY 2027**

### OWNER OF OPERATOR (Co.#100)

Metropolitan Water District of So Calif  
158000 MWD Road  
Parker Dam, CA 92267

### EQUIPMENT LOCATION (Fac.#4586)

MWD - Camino Sub-station  
S. of Water Rd. Exit on I-40  
Needles, CA 92363

### **Description:**

LPG IC ENGINE, EMERGENCY GENERATOR consisting of: Model Year 2024, Engine Family RKHXB02.2TNL.

One Kohler, LPG fired internal combustion engine Model No. KG2204T and Serial No. TBD, Turbo Charged, producing 64 bhp with 4 cylinders at 1800 rpm while consuming a maximum of 690 scf/hr. This equipment powers a Kohler Generator Model No. 36CCL and Serial No. TBD, rated at 48 kW.

### **EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
CO	86.50	gm/bhp-hr
NOx	1.27	gm/bhp-hr
PM10	5.24	gm/bhp-hr
PM2.5	5.24	gm/bhp-hr
SOx	0.37	gm/bhp-hr
VOC	1.12	gm/bhp-hr

### **CONDITIONS:**

Fee Schedule: 7 (g)

Rating: 1 device

SIC: 4941

SCC: 20301001

Location/UTM(Km):  
685E/3857N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Metropolitan Water District of So Calif  
P O Box 54153

Los Angeles, CA 90054

By: **COPY**

**Eldon Heaston**  
Air Pollution Control Officer

1. This stationary, spark-ignited, internal combustion engine, certified in accordance with 40 CFR Part 1048, and its associated control devices shall be installed, operated and maintained according to the manufacturer's emission-related written instructions. Further, the owner/operator shall change only those emission-related settings that are permitted by the manufacturer. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.  
[40 CFR 60.4231(c); 60.4233(c); 60.4234; 60.4243(a)(2)(ii)]
  
2. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.  
[District Rule 204]
  
3. This unit shall be fired on commercial grade Liquefied Petroleum Gas (LPG) fuel only.  
[District Rule 431]
  
4. This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. This unit shall be operated for no more than 100 hours per year for testing and maintenance, excluding compliance source testing.  
[District Rule 1302; 40 CFR 60.4243(d)]
  
5. The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:
  - a. Date of each use and duration of each use (in hours);
  - b. Reason for use (testing & maintenance, emergency, required emission testing);
  - c. Calendar year operation in terms of fuel consumption (in standard cubic feet or gallons) or total hours;
  - d. Records of all inspections, maintenance and repair actions, and  
[District Rule 204; District Rule 1302; 40 CFR 60.4245]
  
6. This equipment may operate in response to an impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time. The engine may be operated no more than 30 minutes prior to the forecasted outage and must be shut down immediately after the utility advises that the outage is no longer imminent or in effect.  
[District Rule 204]
  
7. This unit shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC), Demand Response Program (DRP), Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier.  
[District Rule 204; 40 CFR 60.4243(d)]
  
8. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.  
[District Rule 107(b), Health & Safety Code 39607 & 44341-44342, 17 CCR 93400 et seq., and 40 CFR 51, Subpart A]