



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

G001103

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MARCH 2002

OWNER OF OPERATOR (Co.#1144)

Equilon Enterprises c/o Gilbarco Veeder-Root
7300 West Friendly Avenue
Greensboro, NC 27420-2087

EQUIPMENT LOCATION (Fac.#617)

Dry Gulch Shell
1601 E Main Street
Barstow, CA 923113239

Description:

GASOLINE DISPENSING FACILITY consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
----------	-----------------	---------------------	-------------------

DISPENSING EQUIPMENT

Fuel Type	Quantity
92U	8
89U	8
87U	8

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
P11	BAL	G-70-17-AB
PI	DP	G-70-97-AB

CONDITIONS:

Fee Schedule: 6 (N/A)

Rating: 24 product-nozzles SIC: 5541

SCC: 40600603

Location/UTM(Km):
498E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Equilon Enterprises c/o Gilbarco Veeder-Root
P.O. Box 22087/Attn CMS Mailstop F-76
Greensboro, NC 27420-2087

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

1. The toll-free telephone number that must be posted is 1-800-635-4617.
2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.