



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

G002543

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: DECEMBER 1998

OWNER OF OPERATOR (Co.#422)

Lakeside Mini-Mart
26800 Blue Water Road
Helendale, CA 92342

EQUIPMENT LOCATION (Fac.#1092)

Lakeside Mini-Mart
26800 Blue Water Road
Helendale, CA 92342

Description:

GASOLINE DISPENSING FACILITY consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
----------	-----------------	---------------------	-------------------

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	G-70-
PII	BAL	G-70-

CONDITIONS:

1. The toll-free telephone number that must be posted is 1-800-635-4617.

Fee Schedule: 6 (N/A)

Rating: 1 product-nozzles

SIC: 5541

SCC: 99999999

Location/UTM(Km):
473E/3845N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Lakeside Mini-Mart PO box 1496 Helendale, CA 92342
--

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.