



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

G008287

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: OCTOBER 2019

OWNER OF OPERATOR (Co.#1423)

Pyramid Enterprises Inc.
28368 Constellation Rd Ste 380
Valencia, CA 91355

EQUIPMENT LOCATION (Fac.#2454)

Silverwood Lake Marina
14651 Cedar Circle
Hesperia, CA 92345

Description:

GASOLINE DISPENSING FACILITY consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	2,000	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	G-70-155
PII	BAL	G-70-155
	SL	VR-301

CONDITIONS:

Fee Schedule: 5 (a)

Rating: 2000 gallons

SIC: 5541

SCC: 40600131

Location/UTM(Km):
472E/3808N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pyramid Enterprises Inc.
28368 Constellation Rd Ste 380
Valencia, CA 91355

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

1. The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).

[District Rule 461 - Gasoline Transfer and Dispensing]

2. The owner/operator shall maintain a log of all inspections; maintenance and repairs; and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

[District Rule 461 - Gasoline Transfer and Dispensing]

3. Any modifications or changes to the piping, control fittings, or configurations of the vapor recovery system require prior approval from the District.

[District Regulation XIII - NSR]

4. Pursuant to Executive Order VR-301, vapor vent pipes are to be equipped with Husky 5885 pressure relief valves, or as otherwise allowed by this Executive Order.

[CARB Executive Order VR-301]

5. The owner/operator shall perform the following tests no later than 60 days after initial startup, and at least once every twelve (12) months using the latest adopted version of the required test procedures:

- a. Static Pressure Decay Test per CARB test method TP-201.3B (2-inch test);
- b. Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves per TP-201.1E; and,
- c. Liquid Removal Test (if applicable) per TP-201.6.

The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdaqmd.ca.gov

[District Rule 461 - Gasoline Transfer and Dispensing]

6. The annual throughput of gasoline shall not exceed 500,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility is required to submit to the District an application to modify the permit which may require a Health Risk Assessment (HRA). In addition, public notice and/or a commenting period may be required.

[District Rule 1320 - NSR for Toxic Air Contaminants; District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]

7. The owner/operator must install, maintain, and operate this equipment in compliance with CARB Executive Order G-70-155, with the exception of the exterior coating and P/V valve configuration, which shall be in accordance with Executive Order VR-301. Additionally, hanging hardware must be replaced with Balance EVR type hanging hardware during routine equipment change outs.

[District Rule 461 - Gasoline Transfer and Dispensing, Executive Order VR-102, 40 CFR 63, Subpart CCCCCC]

8. Exterior coating and P/V valve retrofit shall occur no later than April 1, 2013. Records of the retrofit shall be kept on site and available to State and District personnel upon request.

[District Rule 204]