MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

M011032

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2012

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
Bldg 602, 5th Street
Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac.#589)

NTC Training Mission
Bldg. 602, 5th street
Fort Irwin, CA 923105085

Description:
DIESEL IC ENGINE, PORTABLE BACKUP GENERATOR consisting of: Year of Manufacture 2008, Tier 1, Engine Family 2JDXL06.8014, CARB Executive Order U-R-004-0119

One John Deere, P-Gas fired internal combustion engine Model No. 6068TF151 and Serial No. PE6068T720185, producing 134 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 5.0 gal/hr. This equipment powers a MCII Generator Model No. MEP-806B and Serial No. 004089, rated at kw.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.68	gm/bhp-hr
NOx	5.5	gm/bhp-hr
PM10	0.21	gm/bhp-hr
VOC	0.3	gm/bhp-hr

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles, which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

Fee Schedule: 10 (1b) | Rating: 134 bhp | SIC: 9711 | SCC: 20100102 | Location/UTM(Km): 529E/3902N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works
Attn: Air Resources Manager

Fort Irwin, CA 92310

By: **COPY**
Brad Poiriez
Executive Director

UNOFFICIAL

2. This diesel ICE and its associated equipment cannot be operated at the same footprint (spot) for more than 365 consecutive days. (This system must be moved within this facility or moved to another facility annually.)

3. This engine shall not be operated simultaneously with the engine described in District permit B011031, except for one (1) hour to switch engines, and this engine and the engine with District permit B011031 shall not be operated for more than 210 hours per calendar year, combined.

4. This unit shall only be fired on ultra-low sulfur diesel fuel, whose sulfur concentration is less than or equal to 0.0015% or 15 ppm on a weight per weight basis per CARB Diesel or equivalent requirements. (Title 17 CCR Section 93116.3(a))

5. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

6. The o/o shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:
a. Date of each use and duration of each use (in hours);
b. Reason for use (testing & maintenance, emergency, required emission testing);
c. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).

7. The o/o of this unit must submit a Status Report for the entire fleet* by March 1, 2011. This Status Report should include, but not limited to, the following, for details see Title 17 CCR 93116.4(e)(1):

a. The fleet's weighted average PM emission rate for the 2010 calendar year,
b. Inventory of portable engines in the fleet,
c. Identify, if applicable, each portable diesel-fueled engine that the owner commits to replacing with a Tier 4 engine,
d. Listing of portable diesel-fueled engines, if applicable, used exclusively in emergency applications,
e. Listing of portable diesel-fueled engines, if applicable, satisfying the low-use engine requirements,
f. Listing of portable alternative-fueled engines, if applicable, added to the fleet prior to January 1, 2009, pursuant to section 93116.3(d)(2)(B)2, and
g. Listing of portable diesel-fueled engine(s) equipped with Selective Catalytic Reduction (SCR) system(s),

*Fleet is defined in Title 17 CCR Section 93116.2(p) as one or more portable unit(s).

8. The o/o and/or Responsible Official of a fleet electing to use electrification in determining the fleet average shall submit the report required by Title 17 CCR 93116.4(c)(3) by January 1, 2012.

9. The fleet under control of this o/o is subject to and shall comply with the weighted PM emission fleet averages expressed as grams per brake horsepower-hour (g/bhp-hr) by the listed compliance dates in Title 17 CCR Section 93116.3(c).

Fleet Standard Compliance;

Date	Engines <175 bhp (g/bhp-hr)	Engines >175 to 749 bhp (g/bhp-hr)	Engines >750 bhp (g/bhp-hr)
1/1/2013	0.3	0.15	0.25
1/1/2017	0.18	0.08	0.08
1/1/2020	0.04	0.02	0.02

Fleet is defined in Title 17 CCR Section 93116.2(16).

10. The o/o of this unit must submit a Statement of Compliance signed by the Responsible Official that the fleet standards are being achieved and a summary that identifies each portable engine in the fleet and the associated emission rate (g/bhp-hr) and other required information, see Title 17 CCR 93116.4(e)(2), (3), (4), (5), (6) and (7) for the following compliance statement submittal dates:

Weighted DPM Emission Fleet Average Date Submit by
January 1, 2013 March 1, 2013
January 1, 2017 March 1, 2017
January 1, 2020 March 1, 2020

11. This portable equipment shall not be operated and/or located with 1,000 feet of a public or private school (kindergarten through 12th grade) of more than 12 students for more than 45 consecutive days without completing the notification required by Health and Safety Code \S\S 42301.6.

12. This unit is subject to the requirements of the Airborne Toxic Control Measure For Diesel Particulate Matter From Portable Engines Rated At 50 Horsepower and Greater (Title 17 CCR 93116). In the event of conflict between these conditions and the ATCM, the more stringent shall govern.

13. This facility shall emit less than the following on a calendar year basis;
Oxides of Nitrogen (NOx) - 25 tons,
Volatile Organic Compound (VOC) - 25 tons,
Particulate Matter less than 10 microns (PM10) - 15 tons, and
Hazardous Air Pollutants (HAP) - 10 tons per year for any single HAP and 25 tons per year for any combination of HAPs.
Compliance shall be demonstrated annually to the District through the submission of a District approved Comprehensive Emission Inventory Report (CEIR) or other District approved equivalent method. The report shall be submitted to the District no later than April 30 of each year.