



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

N001365

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: DECEMBER 2008**

### **OWNER OF OPERATOR (Co.#202)**

Victor Valley Union H S District  
16350 Mojave Drive  
Victorville, CA 92392

### **EQUIPMENT LOCATION (Fac.#795)**

Victor Valley SD - Vehicle Maintenance Yard  
14801 Mojave Drive  
Victorville, CA 92392

### **Description:**

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

### **FUEL TANKS**

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	10,000	Above Ground
2	Diesel	10,000	Above Ground

### **DISPENSING EQUIPMENT**

Fuel Type	Quantity
Diesel	2
87U	2

### **VAPOR CONTROL EQUIPMENT**

Type	Equipment Name	Compliance
PI	DP	G-70-190
PII	BAL	G-70-155

Fee Schedule: 5 (b)

Rating: 10000 gallons

SIC: 9411

SCC: 40600603

Location/UTM(Km):  
473E/3822N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victor Valley Union H S District  
16350 Mojave Drive  
Victorville, CA 92392

By: **COPY**  
**Brad Poiriez**  
Executive Director

**CONDITIONS:**

1. The toll-free telephone number that must be posted is 1-800-635-4617.
  
2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
  
3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.
  
4. The o/o shall conduct and pass the following tests annually:
  - a. Pressure Decay Tests per CARB test method TP-201.3B.
  - b. Emergency vents and manways shall be leak free when tested at the operating pressure of the tank in accordance with CARB test methods, as specified in Title 17, California Code of Regulations.

Passing test reports shall be received by the District not later than six (6) weeks prior to the expiration date of this permit.

5. Aboveground tank shall be installed and maintained in compliance with CARB Executive Order G-70-190.
  
6. Dispenser and pipe configuration shall be maintained in compliance with Executive Order G-70-155.