



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### PERMIT TO OPERATE

N001811

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: APRIL 2026**

#### OWNER OF OPERATOR (Co. #69)

Southern California Edison  
P.O. Box 5085  
Rosemead, CA 91770

#### EQUIPMENT LOCATION (Fac. #945)

SCE - Victorville  
12353 Hesperia Road  
Victorville, CA 92392

#### Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of: Bulk loading system includes: two position tank truck loading system consisting of: A. One (1) 2" dia. X 8' L. Gasoline hose with an OPW dry break coupler for bottom loading. B. One (1) 3" dia. X 8' L. Gasoline vapor recovery hose with an OPW camlock quick connect 4x3 coupler. C. One (1) 2" dia. X 8' L. Diesel hose with an OPW dry break coupler for bottom loading (exempt).

#### FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	6,000	Above Ground
2	Diesel	6,000	Above Ground

#### DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1
Diesel	1

#### VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	OPW	VR-401

Fee Schedule: 5 (a)      Rating: 6000 gallons      SIC: 4911      SCC: 40600603      Location/UTM(Km): 473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Edison  
P.O. Box 5085  
  
Rosemead, CA 91770

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

Type	Equipment Name	Compliance
PII	BAL	G-70-194

## CONDITIONS:

1.The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).

[District Rule 461 - Gasoline Transfer and Dispensing]

2.The owner/operator shall maintain a log of all inspections, repairs, maintenance, and throughput on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

[District Rule 461 - Gasoline Transfer and Dispensing]

3.Any modifications or changes to the piping or control fittings of the vapor recovery system require prior approval from the District.

[District Regulation XIII - NSR]

4.The Enhanced Vapor Recovery (EVR), Phase I and II Vapor Recovery System must be tested in accordance with the requirements of CARB Executive Order VR-401, no later than 60 days after initial startup, and at least once every twelve (12) months using the latest adopted version of the required test procedures.

The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdaqmd.ca.gov

[District Rule 461 - Gasoline Transfer and Dispensing, Executive Order VR-401]

5.Maintenance and repair of system components, including removal and installation of such components in the course of any required tests, shall be performed by OPW Certified Technicians.

[Executive Order VR-401]

6.Maintenance Intervals for OPW Tank Gauge Components, Dust Caps, Emergency Vents, Phase I Product and Vapor Adapters, and Spill Container Drain Valve, shall be conducted by an OPW trained technician on an annual basis.

[Executive Order VR-401]

7.The owner/operator must install, maintain, and operate EVR Phase I equipment in compliance with CARB Executive Order VR-401, and Phase II equipment in accordance with G-70-194 with the exception that hanging hardware shall be EVR Balance Phase II-type (VST or other CARB Approved EVR Phase II Hardware).

8.The annual throughput of gasoline shall not exceed 600,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.

[District Rule 1320; District Rule 107(b); H&S Code 39607 & 44341-44342, 17 CCR 93400 et seq., and 40 CFR 51, Subpart A]

9.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342, 17 CCR 93400 et seq., and 40 CFR 51, Subpart A]