



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

N003252

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: NOVEMBER 2025

OWNER OF OPERATOR (Co. #1136)

CALTRANS
464 West 4th Street, 6th Floor
San Bernardino, CA 92401-1400

EQUIPMENT LOCATION (Fac. #885)

Caltrans Yard - Essex
11165 National Trails Hwy.
Essex, CA 92332

Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
----------	-----------------	---------------------	-------------------

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1
Diesel	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	CO	G-70-167
PII	BAL	G-70-167

CONDITIONS:

Fee Schedule: 5 (a) Rating: 3000 gallons SIC: 9621 SCC: 40600603 Location/UTM(Km): 660E/3845N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CALTRANS
464 W 4th St, MS1108-Mtce Support
San Bernardino, CA 92401-1400

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

1.The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free telephone number for complaints (1-800-635-4617).

[District Rule 461]

2.The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.

[District Rule 461]

3.Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.

[District Regulation XIII]

4.The gasoline vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by Executive Order (EO) VR-301.

[CARB Executive Order VR-301]

5.The owner or operator shall conduct and pass the following tests annually using the latest adopted version of the following test procedures:

a. Pressure Decay Tests per CARB test method TP-201.3B.

b. Liquid Removal Test (if applicable) per TP-201.6.

c. Emergency vents and manways shall be leak free when tested at the operating pressure of the tank in accordance with CARB test methods, as specified in Title 17, California Code of Regulations.

The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to

VaporRecoveryTesting@mdaqmd.ca.gov

6.The annual throughput of gasoline shall not exceed 60,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.

[District Rule 1320 - NSR for Toxic Air Contaminants; District Rule 107(b); H&S Code 39607 & 44341-44342, 17 CCR 93400 et seq., and 40 CFR 51, Subpart A]

7.The owner/operator shall install, maintain, and operate this equipment in compliance with CARB Executive Order G-70-167, with the exception of the exterior coating and P/V valve configuration, which shall be in accordance with EO VR-301. Additionally, hanging hardware must be replaced with VST Balance EVR type hanging hardware during routine equipment change outs and According to Section 20 of CP-206, when CARB's Executive Officer has determined that EVR components are compatible and commercially available, only EVR components shall be installed when pre-EVR components are replaced.

[CARB Executive Order G-70-167 and Executive Order VR-301]

8.The California Air Resources Board (CARB) has established a timeline for Aboveground Storage Tanks (AST) Enhanced Vapor Recovery (EVR) system implementation. Pursuant to CARB requirements and State mandated retrofits, the o/o shall ensure that this tank meets all the applicable requirements within the designated timeframes; EVR Phase I shall be installed in accordance with CARB AST PI EVR Advisory: <https://www.arb.ca.gov/vapor/advisories/adv367.pdf>