



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

N004461

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JANUARY 2015

OWNER OF OPERATOR (Co.#752)

Palo Verde Irrigation District
180 West 14th
Blythe, CA 92225

EQUIPMENT LOCATION (Fac.#1455)

Palo Verde Irrigation Dist. - W 14th Ave
180 W 14th Avenue
Blythe, CA 92225

Description:

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	12,000	Under Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	2
Diesel	2

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	VR-101-C
PII	HEALY	VR-201-H

CONDITIONS:

Fee Schedule: 5 (b)

Rating: 12000 gallons

SIC: 4971

SCC: 40600603

Location/UTM(Km):
725E/3273N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Palo Verde Irrigation District
180 West 14th
Blythe, CA 92225

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

1. The toll-free telephone number that must be posted is 1-800-635-4617.
2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.
4. The vapor vent pipes are to be equipped with pressure relief valves.
5. The Phase II Vapor Recovery System shall be tested in accordance with the requirements of Executive Order (EO) VR-201-H, as stated herein. The owner or operator shall conduct and pass the following tests ANNUALLY using the latest adopted version of the following test procedures:

- a. TP-201.3, Determination of 2-Inch WC Static Pressure Performance of Vapor Recovery Systems of Dispensing Facilities (March 17, 1999);
- b. Exhibit 8, Required Items in Conducting TP-201.3;
- c. Exhibit 4; Determination of Static Pressure Performance of the Healy Clean Air Separator;
- d. Exhibit 5, Vapor to Liquid Volume Ratio; and
- e. Exhibit 7, Nozzle Bag Test Procedure; and

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.

The District shall receive passing test report no later than six (6) weeks prior to the expiration date of this permit.

6. The Enhanced Vapor Recovery (EVR) 2-Point Phase I System shall be tested in accordance with the requirements of EO VR-101-C, as stated herein. The owner or operator shall conduct and pass the following tests at least once every three years using the latest adopted version of the following test procedures (next set of EVR Phase I testing due in 2012):

- a. Static Torque of Rotatable Phase I Adaptors per TP201.1B;
- b. Depending on system configuration, either TP-201-1D, Leak Rate of Drop Tube Overfill Prevention, Device and Spill Container Drain Valve; or TP-201.1C, Leak Rate of Drop Tube/Drain Valve Assembly; and
- c. P/V valves in accord with TP-201.1E.

Passing test report shall be received by the District no later than six (6) weeks prior to the expiration date of this permit in those years when testing is required.

7. The annual throughput of gasoline shall not exceed 600,000 gallons per calendar year. Throughput records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition, a public notice and/or comment period may be required. These throughputs are established to enable this facility to operate without installing ISD.

Throughput records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition, a public notice and/or comment period may be required. These throughputs are established to enable this facility to operate without installing ISD.

8. Enhanced Vapor Recovery (EVR) 2-Point Phase I Vapor Control Equipment to be maintained in Compliance with Executive Order VR-101-C.

9. Assist EVR Phase II without ISD Equipment to be maintained in Compliance with EO VR-201-H, Dispensers shall be Uni-Hose type.

10. In accordance with the EVR implementation time line, and based on this facilities throughput limit, In-Station-Diagnostics (ISD) is not required. If the o/o wishes to increase throughput allowance, ISD must be installed in accordance with the EVR timeline. Prior to

installing this system, a District approved Authority To Construct permit must be obtained.