



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

N008637

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: MARCH 2013**

**OWNER OF OPERATOR (Co.#46)**

Victorville, City of  
14343 Civic Drive  
Victorville, CA 92392-2399

**EQUIPMENT LOCATION (Fac.#2564)**

Victorville - Parks Dept  
18003 Westwinds Dr/Golf Course  
Victorville, CA 92392

**Description:**

GASOLINE DISPENSING FACILITY (NON-RETAIL) consisting of:

**FUEL TANKS**

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1A	87U	1,000	Above Ground
1B	Diesel	1,000	Above Ground

**DISPENSING EQUIPMENT**

Fuel Type	Quantity
87U	1
Diesel	1

**VAPOR CONTROL EQUIPMENT**

Type	Equipment Name	Compliance
PI	DP	G-70-116-F
PII	BAL	G-70-116-F

Fee Schedule: 5 (a)

Rating: 1000 gallons

SIC: 9199

SCC: 40600603

Location/UTM(Km):  
473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victorville, City of  
Public Works - Fleet Division  
  
Victorville, CA 92392-2399

By: **COPY**  
**Brad Poiriez**  
Executive Director

## **CONDITIONS:**

1. The toll-free telephone number that must be posted is 1-800-635-4617.
  
2. The owner/operator, o/o, shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. This log shall be kept current, on-site for a minimum of 2 years and provided to District personnel on request.
  
3. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District.
  
4. The vapor vent pipes are to be equipped with pressure relief valves.
  
5. The owner or operator shall conduct and pass the following tests annually using the latest adopted version of the following test procedures:
  - a. Pressure Decay Tests per CARB test method TP-201.3B.
  - b. Liquid Removal Test (if applicable) per TP-201.6
  - c. Emergency vents and manways shall be leak free when tested at the operating pressure of the tank in accordance with CARB test methods, as specified in Title 17, California Code of Regulations.

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.

Passing test reports shall be received by the District not later than six (6) weeks prior to the expiration date of this permit.

6. The annual throughput of gasoline shall not exceed 500,000 gallons per year. Throughput Records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment in accord with a District approved plan. In addition public notice and/or comment period may be required.
  
7. The o/o shall maintain and operate this equipment in compliance with CARB Executive Order G-70-116-F.