



# MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

N010301

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: APRIL 2016**

## **OWNER OF OPERATOR (Co.#69)**

Southern California Edison  
P.O. Box 5085  
Rosemead, CA 91770

## **EQUIPMENT LOCATION (Fac.#902)**

SCE - Barstow Service Center  
1820 Rimrock Road  
Barstow, CA 92311

### **Description:**

MOBILE FUEL DISPENSING EQUIPMENT consisting of:

### **FUEL TANKS**

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1A	87U	750	Above Ground
1B	Diesel	750	Above Ground

### **DISPENSING EQUIPMENT**

Fuel Type	Quantity
Diesel	1
87U	1

### **VAPOR CONTROL EQUIPMENT**

Type	Equipment Name	Compliance
PI	DP	G-70-193
PII	AST	G-70-193

Fee Schedule: 5 (a)

Rating: 750 gallons

SIC: 4911

SCC: 40600131

Location/UTM(Km):  
501E/3859N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Edison  
P.O. Box 5085  
  
Rosemead, CA 91770

By: **COPY**  
**Brad Poiriez**  
Executive Director

## **CONDITIONS:**

1. The toll-free telephone number that must be posted is 1-800-635-4617.
  
2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
  
3. Any modifications or changes to the piping or control fitting of the vapor recovery system require prior approval from the District.
  
4. The vapor vent pipes are to be equipped with pressure relief valves.
  
5. This tanker truck shall be equipped and operate in compliance with the National Air Toxic Standards for Gasoline Dispensing Facilities (GDF) (40 CFR 63, Subpart CCCCCC). In the event of conflict with these permit conditions and the NESHAP, the more stringent requirements shall govern.
  
6. Pursuant to District Rule 462(D)(3), Organic Liquid Transport (Tank Truck, Trailer, etc.), prior to dispensing any fuel, this tanker truck shall have a valid certification of vapor integrity as defined by the applicable Air Resources Board Certification and Test Procedures, pursuant to Health and Safety Code Section 41962(9) and the California Administrative Code Title 17, Section 94004.
  
7. The o/o shall perform the following tests annually in accord with the following test procedures:
  - a. Vapor Return Line Vacuum Integrity and test procedure per EO G-70-193 Exhibit 3.
  - b. Fill Pipe Pressure Regulation Fueling Test for the Healy Model 400 ORVR nozzles per EO G-70-193 Exhibit 4.
  - c. Ten-gallon per minute maximum fueling rate compliance verification per EO G-70-193 Exhibit 5.
  - d. Static Pressure Decay Test per CARB test method TP-204.1 (Determination of Five Minute Static Pressure Performance of Vapor Recovery Systems of Cargo Tanks);
  - e. Emergency vents and manways shall be leak free when tested at the operating pressure of the tank in accordance with CARB test methods, as specified in Title 17, California Code of Regulations.
  
- The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.
  
- The District shall receive passing test reports no later than six (6) weeks prior to the expiration date of this permit.
  
8. The annual throughput of gasoline shall not exceed 500,000 gallons per year. Throughput Records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment in accord with a District approved plan. In addition public notice and/or comment period may be required.
  
9. The o/o shall; install, maintain, and operate this equipment in compliance with CARB Executive Order G-70-193.