



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

N011208

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: NOVEMBER 2012**

**OWNER OF OPERATOR (Co.#84)**

NTC - Public Works  
Bldg 602, 5th Street  
Fort Irwin, CA 92310

**EQUIPMENT LOCATION (Fac.#589)**

NTC Training Mission  
Bldg. 602, 5th street  
Fort Irwin, CA 923105085

**Description:**

GASOLINE DISPENSING consisting of:

**FUEL TANKS**

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
200018	87U	1,000	Above Ground

**DISPENSING EQUIPMENT**

Fuel Type	Quantity
87U	1

**VAPOR CONTROL EQUIPMENT**

Type	Equipment Name	Compliance
PI	DP	VR-401-B
PII	BAL	G-70-162-A

**CONDITIONS:**

Fee Schedule: 5 (a)

Rating: 1000 gallons

SIC: 9711

SCC: 40600603

Location/UTM(Km):  
529E/3902N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works  
Attn: Air Resources Manager  
  
Fort Irwin, CA 92310

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

1. The toll-free telephone number that must be posted is 1-800-635-4617.

2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and available to the District upon request. Records of Maintenance, Tests, Inspections, and Test Failures shall be maintained and available to District personnel upon request; record form shall be similar to the Maintenance Record form indicated in EO VR-401-B, Figure 2N.

3. Any modifications or changes to the piping or control fitting of the vapor recovery system require prior approval from the District.

4. Pursuant to EO VR-401-B, vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by EO.

5. The o/o shall perform the following tests within 60 days of construction completion and annually thereafter in accord with the following test procedures:

a. Determination of 2 Inch WC Static Pressure Performance of Vapor Recovery Systems per TP-206.3,

b. Pressure Integrity of Drop Tube/Drain Valve Assembly per TP-201.1C,

c. Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves per TP-201.1E,

d. Phase I Adapters, Emergency Vents, Spill Container Drain Valve, Dedicated gauging port with drop tube and tank components, all connections, and fittings shall NOT have any detectable leaks; test methods shall be per EO VR-401-B Table 2-1, and

e. Liquid Removal Test (if applicable) per TP-201.6.

Summary of Test Data shall be documented on a Form similar to EO VR-401-B Form 1

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.

The District shall receive passing test reports no later than six (6) weeks prior to the expiration date of this permit.

6. Pursuant to California Health and Safety Code sections 39600, 39601 and 41954, this aboveground tank shall be installed and maintained in accordance with Executive Order (EO) VR-401-B for EVR Phase I, and Standing Loss requirements:  
<http://www.arb.ca.gov/vapor/eos/eo-vr401/eo-401.htm>

Additionally, Phase II Vapor Recovery System shall be installed and maintained per G-70-162-A with the exception that hanging hardware shall be EVR Balance Phase II type hanging hardware (VST or other CARB Approved EVR Phase II Hardware).

In the event of conflict between these permit conditions and/or the referenced EO s the more stringent requirements shall govern

7. Pursuant to EO VR-401-B: Maintenance and repair of system components, including removal and installation of such components in the course of any required tests, shall be performed by OPW Certified Technicians.

8. Pursuant to EO VR-401-B, Maintenance Intervals for OPW; Tank Gauge Components; Dust Caps Emergency Vents; Phase I Product and Vapor Adapters, and Spill Container Drain Valve, shall be conducted by an OPW trained technician annually.

9. The annual throughput of gasoline shall not exceed 600,000 gallons per year. Throughput Records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment in accord with a District approved plan. In addition public notice and/or comment period may be required.