



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

N011540

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JULY 2014

OWNER OF OPERATOR (Co.#2052)

Tatitlek Support Services - MCAGCC
MCAGCC
Twentynine Palms, CA 92277

EQUIPMENT LOCATION (Fac.#3371)

Tatitlek FOB4 Camp Wilson
FOB4 Camp Wilson - MCAGCC
Twentynine Palms, CA 92277

Description:

1000 GALLON ABOVE GROUND TANK (Range 220) consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	1,000	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
PI	DP	G-70-194
PII	BAL	G-70-194

CONDITIONS:

Fee Schedule: 5 (a)

Rating: 1000 gallons

SIC: 9711

SCC: 40600603

Location/UTM(Km):
538E/3778N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Tatitlek Support Services - MCAGCC
P.O. Box 995
Twentynine Palms, CA 92277

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

1. The toll-free telephone number that must be posted is 1-800-635-4617. Rule 461]

2. This tank shall meet the requirements of Executive Order (EO) VR-301-C, Standing Loss Control Vapor Recovery System for Existing Installations of Aboveground Storage Tanks signed pursuant to the California Health and Safety Code sections 39600, 39601 and 41954 no later than April 1, 2013. This EO requires that existing Aboveground tanks are coated with an approved material and that the tank be fitted with a Husky 5885 Pressure/Vacuum Valve: <http://www.arb.ca.gov/vapor/eos/eo-vr301/eo-vr301.htm> [Rule 204]

3. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Additionally, the date coating was applied, the company performing the coating and material used shall be recorded. Such logs and records shall be maintained at the facility for at least two (2) years and available to the District upon request. [Rule 461]

4. Any modifications or changes to the piping or control fitting of the vapor recovery system require prior approval from the District. [Rule 204]

5. Pursuant to EO VR-301-C, or subsequent, vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by EO. [Rule 204]

6. The o/o shall perform the following tests within 60 days of construction completion and annually thereafter in accord with the following test procedures:
 - a. Static Pressure Decay Test per CARB test method TP-201.3B (2-inch test);
 - b. Liquid Removal Test (if applicable) per TP-201.6, and
 - c. Emergency vents and manways shall be leak free when tested at the operating pressure of the tank in accordance with CARB test methods, as specified in Title 17, California Code of Regulations.
 - d. Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves per TP-201.1 E,The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests.
The District shall receive passing test reports no later than six (6) weeks prior to the expiration date of this permit. [Rule 204]

7. Phase II Vapor Recovery System shall be installed and maintained per G-70-194 with the exception that hanging hardware shall be replaced with EVR Balance Phase II type hanging hardware (VST or other CARB Approved EVR Phase II Hardware) after on-site spare parts are exhausted. [Rule 204]

8. The annual throughput of gasoline shall not exceed 500,000 gallons per year. Throughput Records shall be kept on site and available to District personnel upon request. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment in accord with a District approved plan. In addition, public notice and/or comment period may be required. [Rule 204; Regulation XIII]

9. The o/o shall; install, maintain, and operate this equipment in compliance with CARB Executive Orders G-70-194 and VR-301-C. In the event of conflict between these permit conditions and/or the referenced EOs the more stringent requirements shall govern. [Rule 204]

10. The California Air Resources Board (CARB) has established a timeline for Aboveground Storage Tanks (AST) Enhanced Vapor Recovery (EVR) system implementation. Pursuant to CARB requirements and State mandated retrofits, the o/o shall ensure that this tank meets all the applicable requirements within the designated timeframes. Prior to conducting any modifications the o/o shall obtain a District approved Authority to Construct (ATC) Permit. See the following link for AST EVR Timeline: http://o3.arb.ca.gov/vapor/asttimeline_123009.pdf [Rule 204]