

## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

### PERMIT TO OPERATE

N014066

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

### **EXPIRES LAST DAY OF: JUNE 2026**

# OWNER OF OPERATOR (Co.#199)

SBCo Fleet Management Department 210 N Lena Road San Bernardino,CA92415-0842

# EQUIPMENT LOCATION (Fac. #3162)

SBCo Fire Station 53 - Baker 72734 Baker Blvd. Baker,CA92309-0622

#### **Description:**

GASOLINE DISPENSING FACILITY, NON-RETAIL consisting of:

#### **FUEL TANKS**

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1A	100U	10,000	Above Ground
1B	Diesel	10,000	Above Ground

### **DISPENSING EQUIPMENT**

Fuel Type	Quantity
87U	1
Diesel	1

# **VAPOR CONTROL EQUIPMENT**

Туре	Equipment Name	Compliance
SL	SL	VR-302
PI	MB	VR-402

Fee Schedule:5 (a) Rating:10000gallons SIC:9224 SCC:40600603 Location/UTM(Km):583E/3905N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

SBCo Fleet Management Department 210 N Lena Road San Bernardino.CA92415-0842

By: COPY

Brad Poiriez

Air Pollution Control Officer

## **CONDITIONS:**

- 1.The toll-free telephone number that must be posted is 1-800-635-4617. [District Rule 461 Gasoline Transfer and Dispensing]
- 2. The owner/operator (o/o) shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request. [District Rule 461 Gasoline Transfer and Dispensing]
- 3.Any modifications or changes to the piping or control fitting of the vapor recovery system require prior approval from the District. [District Regulation XIII NSR]
- 4.Pursuant to California Health and Safety Code sections 39600, 39601 and 41954, this aboveground tank shall be installed and maintained in accordance with Executive Order (EO) VR-402 for EVR Phase I, and EO VR-302, Standing Loss requirements. [District Rule 461 and Executive Order VR-402]
- 5. Pursuant to EO VR-402, vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by the executive order.

[District Rule 461 and Executive Order VR-402]

- 6. Pursuant to EO VR-402, Maintenance and repair of system components, including removal and installation of such components in the course of any required tests, shall be performed by Morrison Bros. Certified Technicians or as allowed by Executive Officer. [District Rule 461 and Executive Order VR-402]
- 7.The owner/operator has elected to operate its fleet with at least 95%+ ORVR vehicles; therefore, this equipment is exempt from Phase II Enhanced Vapor Recovery. To ensure compliance the owner/operator shall keep records of its fleet vehicles, the method by which ORVR is determined, and the percentage of ORVR equipped vehicles, which shall be a minimum of 95%. [District Rule 204 Permit Conditions]
- 8. The owner/operator shall perform the following tests within 60 days of construction completion and annually thereafter in accord with the following test procedures:
- a. Determination of Static Pressure Performance of Vapor Recovery Systems at Gasoline Dispensing Facilities with Aboveground Storage Tanks shall be conducted per EO VR-402 Exhibit 6;
- b. Leak Rate and Cracking Pressure of Pressure/Vacuum Vent Valves per TP-201.1E:
- c. Phase I Adapters, Emergency Vents, Spill Container Drain Valve, Dedicated gauging port with drop tube and tank components, all connections, and fittings shall NOT have any detectable leaks; test methods shall be per EO VR-402-D Table 2-1; and,
- d. Liquid Removal Test (if applicable) per TP-201.6.

Summary of Test Data shall be documented on a Form similar to EO VR-402 Form 1.

The District shall be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdagmd.ca.gov

[District Rule 461 - Gasoline Transfer and Dispensing, Executive Orders VR-402]

9. The annual throughput of gasoline shall not exceed 500,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.

[District Rule 1320 - NSR for Toxic Air Contaminants; District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]

Page 2 of 2 Permit: N014066 Issue Date: 07/09/2025