

MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

N014521

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MAY 2023

OWNER OF OPERATOR (Co.#199)

SBCo Fleet Management Department 210 N Lena Road San Bernardino,CA92415-0842

EQUIPMENT LOCATION (Fac. #4224)

SBCo - Trona Road Yard 80311 Trona Road Trona,CA93562

Description:

GASOLINE DISPENSING FACILITY, NON-RETAIL consisting of:A 500 gallon capacity, ConVault, model: CVT500G, serial: TBD, equipped with OPW Phase I EVR. Note: Facility elected to paint the tank with PPC Enviro-Clad 2600 White (100) paint Base (A) and Enviro-Clad 2600 Catalyst (B) to comply with the standing loss requirements.(http://convault.com/Content/pdfs/eo301b_final.pdf). Facility elevation is 1647 feet above MSL.

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
1	87U	500	Above Ground

DISPENSING EQUIPMENT

Fuel Type	Quantity
87U	1

VAPOR CONTROL EQUIPMENT

Туре	Equipment Name	Compliance
PI	OPW	VR-401

CONDITIONS:

1. The owner/operator shall conspicuously post, in the gasoline dispensing area, the operating instructions and the district's toll-free

Fee Schedule:5 (a) Rating:500gallons SIC:9199 SCC:40600603 Location/UTM(Km):466E/3957N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

SBCo Fleet Management Department 210 N Lena Road San Bernardino.CA92415-0842

By: COPY
Brad Poiriez
Air Pollution Control Officer

telephone number for complaints (1-800-635-4617). [District Rule 461]

- 2.The owner/operator shall maintain a log of all inspections, repairs, and maintenance on equipment subject to Rule 461. Such logs or records shall be maintained at the facility for at least two (2) years and available to the District upon request. [District Rule 461: Executive Order VR-401]
- 3. The owner/operator has elected to maintain this equipment as exempt from Phase II Enhanced Vapor Recovery requirements by refueling a fleet with at least 95%+ ORVR vehicles. To ensure compliance the owner/operator shall keep records of the make, model, model year, and Vehicle Identification number of all vehicles refueled at the facility. These records shall be maintained on the premises for at least two (2) calendar years.

[District Rule 461(D)(3) and (E)(6) - Gasoline Transfer and Dispensing]

- 4.Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District. [District Regulation XIII]
- 5. Pursuant to California Health and Safety Code sections 39600, 39601 and 41954, this aboveground tank shall be installed and maintained in accordance with Executive Order (EO) VR-401 for EVR Phase I. Vapor vent pipes are to be equipped with Husky 5885 pressure relief valves or as otherwise allowed by the Executive Order.

 [Executive Order VR-401]
- 6.The Enhanced Vapor Recovery (EVR), Phase I Vapor Recovery System must be tested in accordance with the requirements of CARB Executive Order VR-401, no later than 60 days after initial startup, and at least once every twelve (12) months using the latest adopted version of the required test procedures.

The District must be notified a minimum of 10 days prior to performing the required tests with the final results submitted to the District within 30 days of completion of the tests. Testing notifications and testing results may be sent to VaporRecoveryTesting@mdagmd.ca.gov

[District Rule 461 - Gasoline Transfer and Dispensing, Executive Order VR-401]

7.The annual throughput of gasoline shall not exceed 60,000 gallons per year. Throughput records shall be kept on site and available to District personnel upon request, and annual throughput for the previous calendar year shall be provided to the District not later than the end of February of each year. Before this annual throughput can be increased the facility may be required to submit to the District a site specific Health Risk Assessment (HRA) in accord with a District approved plan. In addition a public notice and/or comment period may be required.

[District Rule 1320; District Rule 107(b); Health & Safety Code 39607 & 44341 - 44342; 40 CFR 51, Subpart A]

8.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]