



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**PERMIT TO OPERATE**

T000102

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: JULY 2026**

**OWNER OF OPERATOR (Co.#2)**

CALNEV Pipe Line, LLC  
1001 Louisiana Street  
Houston, TX 77002-5089

**EQUIPMENT LOCATION (Fac.#353)**

CALNEV - Barstow Terminal  
34277 Daggett-Yermo Road  
Daggett, CA 92327

**Description:**

PETROLEUM PRODUCT STORAGE TANK consisting of: Petroleum Product Storage Tank #325: Diesel/Low RVP product, cone roof and floating pan construction with a maximum capacity of 11,662 barrels

**CONDITIONS:**

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles in a manner consistent with good air pollution control practice for minimizing emissions. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[40 CFR 63.11085, District Rule 1302(C)(2)(a)]

2. The maximum True Vapor Pressure (TVP) of organic liquids stored in this tank shall not exceed 0.75 psi (5.2 kPa) under actual storage conditions.

[40 CFR 60.112b, Rule 463(C)(1)]

3. The owner/operator shall maintain an operations log for each day's operations (from midnight to midnight) which shall include, as a minimum, the following information. This log shall be kept current and on-site (or at a central location) for a minimum of five (5) years, and shall be provided to District, State and Federal personnel upon request:

- a. The aggregated total amount of petroleum products transferred from the supplying pipelines and tanker trucks into all storage tanks combined, by product type and CAS, in gallons;
- b. Average volume of petroleum products stored onsite;

Fee Schedule: 5 (c)

Rating: 500000 gallons

SIC: 5171

SCC: 40400122

Location/UTM(Km):  
510E/3859N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CALNEV Pipe Line, LLC  
1001 Louisiana Street  
  
Houston, TX 77002-5089

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

- c. Storage and transfer temperatures of petroleum products, in degrees Fahrenheit;
- d. Monthly summary of incoming and outgoing petroleum product throughput, in gallons;
- e. Running consecutive twelve (12) month summary of incoming and outgoing petroleum product throughput, in gallons;
- f. Records of all inspections;
- g. Records of all maintenance and repair procedures;
- h. Records of all tank emptyings and refillings; and
- i. Records of the occurrence and duration of each malfunction of operation and what corrective actions were taken to minimize emissions.

[40 CFR 70.6(a)(3)(ii)(b), District Rule 463]