



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T000110

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JULY 2014

OWNER OF OPERATOR (Co.#2)

CALNEV Pipe Line, LLC
1001 Louisiana Street
Houston, TX 77002-5089

EQUIPMENT LOCATION (Fac.#255)

CALNEV - George Terminal
Air Expressway, East of Phantom
Victorville, CA 92394

Description:

TANK consisting of: JP-8 Jet Fuel Storage, 30,000 barrel (1,260,000 gallons) capacity, fixed roof with internal-floating type cover. Tank No. 212. Total - 1,260,000 gallons.

CONDITIONS:

1. Organic liquids having a true vapor pressure of 569 mm Hg (11 psi) absolute or greater under actual storage conditions cannot be stored in this tank (Rule 463).
2. District must be notified in writing if a change is made in type of product to be stored in this tank.
3. The equipment shall be maintained and operated in accordance with local and state certification requirements.
4. The floating roof shall be floating at all times except during initial fill and when tank is completely emptied and subsequently refilled.
5. The permittee shall maintain a record of petroleum product stored, period of storage and amount, storage temperature and maximum true vapor pressure of that product during its storage period. Records shall be maintained for at least two years and made available to District personnel upon request.

Fee Schedule: 5 (c)

Rating: 1260000 gallons

SIC: 5171

SCC: 9999999

Location/UTM(Km):
466E/3826N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CALNEV Pipe Line, LLC
1001 Louisiana Street

Houston, TX 77002-5089

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

6. Unobstructed gap measurement and inspection of the seal along its full length shall be performed within 60 days of initial fill and at least once every five years thereafter, with annual inspections performed at four random seal locations.

7. The permittee shall notify the District when unobstructed seal gap test will occur and supply the District with a written report of seal gap measurements within 60 days after each such test.