



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T001100

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2016

OWNER OF OPERATOR (Co.#2830)

Trogon Development, LLC
37000 Santa Fe Street
Daggett, CA 92327

EQUIPMENT LOCATION (Fac.#1880)

Coolwater Generating Station
37000 Santa Fe Street
Daggett, CA 92327

Description:

TANK NO. 1 - STORAGE consisting of: Fixed roof storage tank with dimensions of 100' diameter x 43'H. The total volume is 2.52 million gallons.

CONDITIONS:

1. Only diesel fuel shall be stored in this tank.
[District Rule 1302(C)(2)(a)]

2. The sulfur content of the diesel fuel stored, shall be ultra-low diesel fuel, whose sulfur concentration is less than or equal to 0.0015% (15 ppm) on a weight per weight basis per CARB Diesel or equivalent requirements.
[District Rule 431]

3. An operator's log shall be maintained which records, as a minimum, the date and amount of diesel fuel received and the sulfur content of the diesel fuel. The log shall be kept on-site for at least two years and made available to District personnel upon request.
[District Rule 1302(C)(2)(a)]

4. The total emissions from this facility shall not equal or exceed any of the following limits in any twelve month period, verified by condition 5:

- a. NOx - 20 tons per year
- b. CO - 80 tons per year
- c. VOC - 20 tons per year
- d. SOx - 80 tons per year
- e. PM10 - 80 tons per year

Fee Schedule: 5 (d)

Rating: 2520000 gallons

SIC: 4911

SCC: 99999999

Location/UTM(Km): 513E/3861N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Trogon Development, LLC
P.O. Box 1605
Canovanas, PR 00729

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

- f. Any single Hazardous Air Pollutant - 8 tons per year
 - g. Any combination of Hazardous Air Pollutants - 20 tons per year
- [District Rule 1200 and District Rule 1302(C)(2)(a)]

5. The facility must submit accurate emissions inventory data to the District, in a format approved by the District, upon District request.
[District Rule 1302(C)(2)(a)]