



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T001542

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: DECEMBER 2000

OWNER OF OPERATOR (Co.#248)

Sunray Energy, Inc
35100 E Santa Fe Road
Daggett, CA 92327

EQUIPMENT LOCATION (Fac.#899)

Sunray Energy - SEGS I
35100 E Santa Fe Road
Daggett, CA 92327

Description:

ULLAGE SYSTEM TANKS HTF consisting of:

EQUIPMENT

Capacity	Equipment Description
1000000	(gallons) Hot Oil Tank, T-1001
1200000	(gallons) Cold Oil Tank, T-102

CONDITIONS:

1. Equipment shall only be operated when vented to functioning Air Pollution Control equipment covered by permit C001541.
2. These tanks shall be equipped with pressure relief valves rated at six (6) inches of water.

Fee Schedule: 5 (d)

Rating: 2200000 gallons

SIC: 4911

SCC: 99999999

Location/UTM(Km):
515E/3858N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Sunray Energy, Inc
PO Box 338
Daggett, CA 92327

By: **COPY**
Eldon Heaston
Air Pollution Control Officer