



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

T001958

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: NOVEMBER 2026

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
Bldg 602, 5th Street
Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac.#589)

NTC Training Mission
Bldg. 602, 5th street
Fort Irwin, CA 923105085

Description:

STORAGE TANK #7706 (CARB DIESEL) consisting of: 100,000 Gallon, Steel, aboveground, equipped with delivery truck vapor return system. Truck fill stand dispensers equipped with extensions for submerged fill.

EQUIPMENT

Capacity	Equipment Description
100000	Tank

CONDITIONS:

1. This bulk plant shall comply with all requirements of District Rule 462. [Rule 204]
2. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which permit is issued unless otherwise noted below. [Rule 204]
3. This equipment shall be operated/maintained in strict accord with manufacturer's/supplier's recommendations and/or sound engineering principles. [Rule 204]

Fee Schedule: 5 (c)

Rating: 100000 gallons

SIC: 9711

SCC: 99999999

Location/UTM(Km):
529E/3902N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works
Attn: Air Resources Manager

Fort Irwin, CA 92310

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

4. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District. [Rule 204]

5. The o/o shall prepare and maintain a log showing both the daily and summary of the throughput for the calendar year to date. The log shall be maintained on-site for two (2) years and be made available to the District upon request. [Rule 204]

6. This equipment shall only store and dispense CARB Low Sulfur Diesel fuel. [Rule 204]