



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

T002277

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: OCTOBER 2004**

**OWNER OF OPERATOR (Co.#31)**

Southern California Gas Co. - MD  
9400 Oakdale Avenue  
Chatsworth, CA 91313

**EQUIPMENT LOCATION (Fac.#69)**

SCG - No Needles Compressor Station  
4500 Needles Highway  
Needles, CA 92363

**Description:**

STORAGE TANK, ODORANT consisting of:

**EQUIPMENT**

Capacity	Equipment Description
0.35	Aboveground odorant storage tank (350 gallons, Captan 50 blend)

**CONDITIONS:**

1. The owner/operator (o/o) shall operate this equipment in strict accord with the manufacturer's specifications and/or sound engineering principles.
2. The o/o shall monitor this tank daily for leaks and comply with MDAQMD Rule 430 - Breakdown Provisions.
3. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
4. This tank and the delivery truck used to fill this tank must be equipped with a Two Point Phase I type vapor recovery system.

Fee Schedule: 5 (a)

Rating: 350 gallons

SIC: 4922

SCC: 30600811

Location/UTM(Km):  
718E/3865N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

<p>Southern California Gas Co. - MD PO Box 2300, SC 9314 Chatsworth, CA 91313-2300</p>
--

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

5. A Two Point Phase I type vapor recovery system must be utilized whenever this tank is being filled.
  
6. This tank shall not be filled to greater than 90% of its maximum capacity (to allow for expansion within tank).