



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

T002854

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: FEBRUARY 2004**

### **OWNER OF OPERATOR (Co.#508)**

Union Pacific Railroad Co  
2015 S Willow St. Manager of Env Field Ops  
Bloomington, CA 92316

### **EQUIPMENT LOCATION (Fac.#1179)**

UPRR Yermo Yard  
1 Union Pacific Blvd  
Yermo, CA 92398

#### **Description:**

DIESEL STORAGE TANK NO. 1 consisting of: 80' dia x 40'h, steel, fixed roof, aboveground. Capacity: 35,000 bbls. (1,470,000).

#### **CONDITIONS:**

1. Diesel fuel stored shall have a sulfur content of not more than 0.05% by weight.
2. The owner/operator (o/o) shall log all deliveries of this fuel including the volume (or weight), date received and the sulfur content. The o/o may use the supplier's sulfur analytical data, but at least annually a sample of the fuel shall be taken and submitted for analysis by an independent laboratory/testing firm. The results of all analyses shall be logged.
3. The o/o shall maintain the logs on-site for a minimum of two (2) years and provide them to District personnel on request.

Fee Schedule: 5 (c)

Rating: 1470000 gallons

SIC: 4013

SCC: 99999999

Location/UTM(Km): 518E/3863N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Union Pacific Railroad Co  
2401 E. Sepulveda Blvd.

Long Beach, CA 90810

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer