



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

T003305

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: NOVEMBER 2003**

**OWNER OF OPERATOR (Co.#86)**

MAGTFTC MCAGCC  
Box 788110, Bldg 1418  
Twentynine Palms, CA 92278-8110

**EQUIPMENT LOCATION (Fac.#591)**

USMC AGCC  
Box 788110, Bldg. 1451  
Twentynine Palms, CA 922788110

**Description:**

FUEL TANK FARM (JP-5 & JP-8) @ HELO FUEL FARM (EAF) consisting of: Three (3) trailer-mounted 600 gallon per minute centrifugal pumps, two (2) for pumping fuel to issue point and one (1) for off-loading fuel from various sources. Each pump is powered by an internal combustion engine rated at 67 hp and the following fuel bladders:

**EQUIPMENT**

Capacity	Equipment Description
20000	Tank #1 - 20'w x 24'l x 5.75'h
20000	Tank #2 - 20'w x 24'l x 5.75'h
20000	Tank #3 - 20'w x 24'l x 5.75'h
20000	Tank #4 - 20'w x 24'l x 5.75'h
50000	Tank #5 - 25'w x 65'l x 5'h
50000	Tank #6 - 25'w x 65'l x 5'h

**CONDITIONS:**

1. Only JP-5 or JP-8 fuel shall be stored in these bladders.
2. All flanges, seals, pumps and other appurtenant equipment shall be maintained to prevent loss of volatile fractions.

Fee Schedule: 5 (c)

Rating: 180000 gallons

SIC: 9711

SCC: 99999999

Location/UTM(Km):  
587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC  
Box 788110, Building 1418  
Twentynine Palms, CA 92278-8110

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

3. The owner/operator (o/o) shall maintain an operator's log for this tank which as a minimum contains the daily throughput, amount received and dispensed.
  
4. The o/o shall comply with all applicable Rules and Regulations of the District. Applicable rules include, but are not necessarily limited to, Regulation IV.
  
5. This equipment shall only be operated/maintained in strict accord with manufacturer's/supplier's recommendations and/or sound engineering principles.