MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

RENEWAL

T003306

Renewal type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2026

OWNER OF OPERATOR (Co.#86)

MAGTFTC MCAGCC
Box 788110, Bldg 1418
Twentynine Palms, CA 92278-8110

EQUIPMENT LOCATION (Fac.#3248)

USMC AGCC - USMC MWSS 374
Box 788110, Bldg. 1451
Twentynine Palms, CA 92278

Description:
FUEL TANK FARM (Jet A) AT FIXED WING/ HELO FUEL FARM (EAF) consisting of: Any number of fuel storage (TFDS) bladders with a combined storage capacity of 100,000 gallons, manifolded together, supporting the Refueling Facility (T008628); and two 600 gallon per minute pumps powered by a 96 bhp electric motor. Fuel is Jet A.

EQUIPMENT

Capacity	Equipment Description
10	100,000 gallon total capacity TFDS Bladder

CONDITIONS:

1. Only Jet A jet fuel shall be stored in these bladders.

2. All flanges, seals, pumps and other appurtenant equipment shall be maintained to prevent loss of volatile fractions.

3. The owner/operator, o/o, shall maintain an operator's log for each tank, which at a minimum contains the following. Such a log or records shall be maintained at the facility for at least 2 years and shall be made available to the APCO upon request;
a. daily throughput, amount received and dispensed,

Fee Schedule: 5 (c) | Rating: 100000 gallons | SIC: 9711 | SCC: 99999999 | Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC
Box 788110, Building 1418

Twentynine Palms, CA 92278-8110

By: **COPY**
Brad Poiriez
Executive Director

UNOFFICIAL

b. true vapor pressure of the liquid stored, and
c. inspections, repairs and maintenance on equipment.

4. This equipment shall be operated/maintained in strict accord with manufacturer's/supplier's recommendations and/or sound engineering principles.

5. This facility shall comply with District Rule 222-Limitations on Potential to Emit. Compliance with this rule will be demonstrated to the District on an annual basis through the submission of an approved Comprehensive Emission Inventory Report (CEIR). A copy of the most recent CEIR shall be maintained on-site and presented to District personnel upon request.