



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

T003308

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: NOVEMBER 2026

OWNER OF OPERATOR (Co.#86)

MAGTFTC MCAGCC
Box 788110, Bldg 1418
Twentynine Palms, CA 92278-8110

EQUIPMENT LOCATION (Fac.#3252)

USMC AGCC - USMC Utilities
Box 788110, Bldg. 1451
Twentynine Palms, CA 92278

Description:

FUEL TANK FARM (BLDG 1577) consisting of: The following tanks and a circulating fuel pump powered by a 50 bhp electric motor.

EQUIPMENT

| Capacity | Equipment Description |
|----------|---|
| 5 | 50,000 gallon Diesel Fuel Storage Tank (horizontal, 12' D by 60' L) - Tank No. 7 |
| 5 | 50,000 gallon Diesel Fuel Storage Tank (horizontal, 12' D by 60' L) - Tank No. 8 |
| 5 | 50,000 gallon Diesel Fuel Storage Tank (horizontal, 12' D by 60' L) - Tank No. 6 |
| 5 | 50,000 gallon Diesel Fuel Storage Tank (horizontal, 12' D by 60' L) - Tank No. 9 |
| 5 | 50,000 gallon Diesel Fuel Storage Tank (horizontal, 12' D by 60' L) - Tank No. 10 |
| 5 | 50,000 gallon Diesel Fuel Storage Tank (horizontal, 12' D by 60' L) - Tank No. 11 |

CONDITIONS:

1. Only Number 2 Diesel fuel or biodiesel B20 fuel shall be stored in this tank farm.
2. All flanges, seals, pumps and other appurtenant equipment shall be maintained to prevent loss of volatile fractions.

Fee Schedule: 5 (c)

Rating: 300000 gallons

SIC: 9711

SCC: 9999999

Location/UTM(Km):
587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC
Box 788110, Building 1418

Twentynine Palms, CA 92278-8110

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

3. The owner/operator (o/o) shall maintain an operator's log of these tanks which as a minimum contains the daily throughput amount received and dispensed.

4. This equipment shall only be operated/maintained in strict accord with manufacturer's/supplier's recommendations and/or sound engineering principles.