



# MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA92392-2310  
760.245.1661 -- 800.635.4617 -- FAX760.245.2022

## INACTIVE

T003310

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: NOVEMBER 2004**

### OWNER OF OPERATOR (Co.#86)

MAGTFTC MCAGCC  
Box 788110, Bldg 1418  
Twentynine Palms, CA92278-8110

### EQUIPMENT LOCATION (Fac.#591)

USMC AGCC  
Box 788110, Bldg. 1451  
Twentynine Palms, CA922788110

#### **Description:**

FUEL TANK FARM AT BLDG 1577 consisting of: a fuel tank, Number 8, for storage and handling of No. 2 diesel. The tank is 12 ft in diameter and 60 ft long and whose capacity is 50,000 gal. Note: This tank farm consists of 6 of these tanks numbered 6 - 11 (District permits T003308 through T003313) and a circulating fuel pump, which is powered by a 50 hp electric motor.

#### **CONDITIONS:**

1. The owner/operator, o/o, shall comply with all rules and regulations of this District. Applicable rules include, but are not limited to those in Regulation IV.
2. The o/o shall operate and maintain this unit in strict accord with the recommendations of the manufacturer and or sound engineering practices, which produce the minimum emissions of contaminants.
3. The o/o shall maintain a log, which contains as a minimum, the daily throughput, volume received and dispensed. This log shall be kept current, on-site for a minimum of 2 years and provided to District personnel on request.
4. This tank is limited to the receiving of Number 2 Diesel, whose sulfur concentration is less than 0.05% by weight. Higher sulfur concentrations may currently be present until the dilution of the older supplies, to the 0.05% level is achieved.
5. All flanges, seals, pumps and other appurtenant equipment shall be maintained to prevent the loss of volatile fractions.

Fee Schedule: 5 (b)

Rating: 50000 gallons

SIC: 9711

SCC: 99999999

Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC  
Box 788110, Building 1418  
Twentynine Palms, CA92278-8110

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer